

✓ SLM

9/29/2026 9:43:06 AM

WORK ORDER

Jeremy Herendon DBA Herendon Homes

357 Spring Ridge
Morganton, GA 30560
(770) 634-1498

Customer #: 206363
Order #: 547995
Location #: 282609
Zone: B-008-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 10/2/26 Connect and convert stove kit on site. Call
770-634-1498 CDD-SLM

Email Invoice

Date Ordered: 9/29/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service: 7/28/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206363

Name: JEREMY HERENDON

Address: 357 SPRING RIDGE

MORGANTON GA 30560

Date: 10/2/26

Instructions: CONNECT AND CONVERT STOVE KIT ON SITE

CALL 770-634-1498 COD-SLM

Order #: 547995

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	Z-line					
Model #	SGR36-A2					
Serial #	SGR36SE260701301CN-00					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2601320	Good	Triarc	2026	V.G	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9 04-2026	☒ Correct ☐ Incorrect		
2nd	Rego	LV3403B4 04-2025	☒ Correct ☐ Incorrect	11.3	13.9

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
70 PSI	70 PSI	10 Mins	☒ Yes ☐ No	15 PSI	15 PSI	10 Mins	☒ Yes ☐ No
WC	WC	Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206363

Date: 7-28-26

Name: JEREMY HERENDON DBA HERENDON HOMES

Instructions: T/I 500UG W/ 50G @ 2.499 HOLE WILL BE
DUG. 4 DROPS T/I 7.5 RINNAI W/H 770-634-1498 SM

Address: 357 SPRING RIDGE
MORGANTON GA 30560

Order #: 523770

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
			1.5 HR	100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to 3 year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$ 1673.00	\$ 1299.95	
Standard Vent Kit	\$ 426.95	\$ 0.00	
Standard Install	\$ 400.00	\$ 0.00	
Total	\$ 2499.95	\$ 1499.95	1499.95

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499	
Gallons	50	Gallons	50	
FRCC	\$9.79	FRCC	\$9.79	9.79
Fuel Total	149.95	Fuel Total	124.95	124.95
Tank Lease/YR	129.95	1st yr Lease	FREE	FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250 Tank Set Fee 20.00 20.00

Safety Inspection \$129.95 \$29.95 29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings 1537.80

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE