

✓SUM

9/28/2026 1:38:34 PM

WORK ORDER

MATT WHEELIS

1133 SCENIC MTN VIEW RD
BLUE RIDGE, GA 30513
(770) 823-8777

Customer #: 19613
Order #: 547752
Location #: 246811
Zone: B-016-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 10/2/26 Swap 120AG from 250AG W/200G @ 2.999 Need to
run yard line to house ~~may need to connect 2 dual fuel furnaces~~
and WH. Call 770-823-8777 CCOF Amex ending in 3009. SLM

*Cut off valve
FOR STOVE UNDER FLOOR*

Date Ordered: 9/28/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name: Heating System

Last Service: 3/5/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: **19613**

Name: **MATT WHEELIS**

Address: **1133 SCENIC MTN VIEW RD
BLUE RIDGE GA 30513**

Date: **10/2/26**

Instructions: **SWAP 120AG FOR 250AG W/200G @ 2.999
NEED TO RUN YARD LINE FROM TANK TO HOUSE MAY
NEED TO CONNECT 2 DUAL FUEL FURNANCE AND W/H
Order #: **CALL 770-823-8777 USE AMEX ON FILE 3009
547752** SLM**

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Furnace	Furnace	Water heater	Stove		
Manufacturer	Rheem	Rheem	Navien	Samsung		
Model #	RCF2475TANMC	W382526403	NPE-240A2	NXS8FE3500SS		
Serial #	W242517599	W382526403	20870256147406	51997DDH805147R		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2150276	good	Arcosa	2021	Ag	good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Reyo	3TR9	☒ Correct ☐ Incorrect		
2nd	Reyo	3BU	☒ Correct ☐ Incorrect	11.5	13.6

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Brandon Pige	Service Technician (Signature)	Brandon Pige	Date	10/2/26
Customer (Print)	MATTHEW WHEELIS	Customer (Signature)	Matt Wheelis	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 19613
Name MATT WHEELIS
Address 1133 SCENIC MTN VIEW RD
BLUE RIDGE GA 30513

Date: 10/2/26

Instructions: SWAP 120AG FOR 250AG W/200G @ 2.999
RUN YARD LINE CONNECT 2 DUAL FUEL FURNACES AND
W/H GCOF- ENDING 3009 AMEX CALL 770-823-8777 SLM
Order #: 547752

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.999
Gallons	200	Gallons	200
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	599.80	Fuel Total	599.80
Tank Lease/YR	99.00	1st yr Lease	99.00

Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 350.00

Safe Appliance Rebate 250.00

TOTAL BALANCE DUE