

8/27/2026 9:29:29 AM

WORK ORDER

RONNIE WILLIAMS

14 Green Way
Blairsville, GA 30512
(863) 224-3613

Customer #: 40152
Order #: 537602
Location #: 247608
Zone: B-011-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 09/02/26 - GO AFTER LUNCH! C/C STOVE - KIT ON SITE -
\$25 HAUL OFF OLD UNIT CALL 863-224-2538 - CCOF - CT

Date Ordered: 8/27/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name: Heating System	Last Service:	Last Tune Up:		
Contract:	SC Renewal:			
Manufect:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 30152

Name: RONNIE WILLIAMS

Address: 14 GREEN WAY

BLAIRSVILLE, GA 30512

Date 9/2/26

Instructions: GO AFTER LUNCH! C/C/ STOVE KIT ON SITE

\$25 HAUL OFF OLD UNIT CALL 863-224-2538

Order #: 537602

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove								
Manufacturer	GE								
Model #	46570072001								
Serial #	MD482818P								
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	M2156869	Good	TRARC	2021	49	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	REGO	LR3403TR NV	☒ Correct ☐ Incorrect		
2nd	REGO	LR3403BA NV	☒ Correct ☐ Incorrect	16.1	12.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
112 PSI	110 PSI	10 Mins	☒ Yes				☐ Yes
			☐ No				☐ No

Comments

Customer Acknowledgment:

- I acknowledge, by checking each of the following items, that:
- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
 - ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
 - ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
 - ☒ I have smelled propane gas and can detect its odor.
 - ☒ I have been told to consider installing one or more gas detectors.
 - ☒ I have received safety information and told to read it and share it with all family members.
 - ☒ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Alvin G. Williams	[Signature]	9-2-26
Customer (Print)	Customer (Signature)	Date
KATNY WILLIAMS	Kathy Williams	9-2-26



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206380

Ronnie Williams - Job

Date: 7-17-26

Name: BRANDON MATHIS

(Builder)

Instructions: DELIVER 325UG W/ 50G @ 2.499 ANODE
BAG 706-455-1238 KN

Address: WILSCOTT WINDS LOT #4

Order #: 524414

MORGANTON GA 30560

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499
Gallons	50	Gallons	50
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	149.95	Fuel Total	129.95
Tank Lease/YR	129.00	1st yr. Lease	FREE

Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 494.78

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE