



congerlpgas.com

INVOICE / WORK ORDER NO.

122380

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Tim McMillan RT# EV RT. SEQ. \_\_\_\_\_ ACCT # 1-02186 DATE 1/21/26 INT 1/2

MAILING ADDRESS \_\_\_\_\_ CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS 3255 McMillan Rd. APT/LOT NO. \_\_\_\_\_

CITY Enigma STATE GA ZIP CODE 31749

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED:  CASH  CHARGE DATE PROMISED \_\_\_\_\_

email: southern grace farms@gmail.com  
cell # 229-646-4180

PAY BILL ONLINE @congerlpgas.com

Repipe house, purchase and install Rinnai

DIRECTIONS: \_\_\_\_\_

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>500</u>	<u>1E048433</u>	<u>0</u>	<u>ON SITE</u>					
		<u>RE180 Rinnai</u>		<u>TJUA-128404</u>					<u>1199.95</u>

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>170'</u>	<u>3/4 Poly</u>				<u>161 50</u>
<u>2</u>	<u>TRANSITIONS 3/4 Poly</u>				<u>89 90</u>
<u>2</u>	<u>COUPLINGS 3/4 Poly</u>				<u>89 90</u>
<u>1</u>	<u>MISC BT</u>				<u>30 00</u>
<u>6</u>	<u>B46R</u>				<u>89 95</u>
<u>10</u>	<u>Flare mps 1/2</u>				<u>29 50</u>
<u>18'</u>	<u>1/2 Copper</u>				<u>107 10</u>
<u>1</u>	<u>1/2 SWIVEL</u>				<u>4 95</u>
<u>1</u>	<u>1/2 msp</u>				<u>3 95</u>

WORK PERFORMED: <u>ran lines to home, installed Rinnai</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
MAKE: <u>Reso</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	
DATE CODE: <u>04E202</u>	VENT: <u>Down</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST			SALES TAX _____ %	LABOR
	HIGH:	1st Stage	2nd Stage		
	START LOCK-UP:	<u>10</u> PSI	PSI	START LOCK-UP:	<u>540 00</u>
	TANK OFF: PRESSURE	<u>6</u> PSI	PSI	TANK OFF: PRESSURE	<u>71 74</u>
	AFTER 10 MINUTES: PRESSURE AS LEFT:	<u>0</u> PSI	PSI	AFTER 10 MINUTES: PRESSURE AS LEFT:	<u>(200 00)</u>
		<u>W</u> PSI	PSI		
PIPING PRESSURE TEST				INV. TOTAL	<u>2,449.91</u>
START _____ PSIG FINISH _____ PSIG				AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

TS SERVICE REP. SIGNATURE      2/6/26 DATE      \_\_\_\_\_ CUSTOMER SIGNATURE