



congerlpgas.com

INVOICE / WORK ORDER NO.

Ga:

122200

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Joyce webb RT# _____ RT. SEQ. _____ ACCT # 01-60788 DATE 12/22/15 INT MP

MAILING ADDRESS _____ CO. _____ CITY _____
ADDRESS 439 William Gibbs Rd APT/LOT NO. _____
CITY Tifton STATE GA ZIP CODE 31793

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

email: Steve Webb
cell # 339 7853

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: water valve right of Building floor put turned over

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rheem Tank Water Heater	Pro 629-30P	RH63 Q192552583		899.00

WORK PERFORMED: <u>Replaced tank water heater</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	899.00
MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED		
DATE CODE: <u>06-2019</u>	VENT: <u>Down</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST			SALES TAX _____ %	LABOR	<u>18.95</u> <u>71.92</u> <u>152</u> <u>86</u> <u>180.00</u> <u>10.80</u> <u><200.00></u>
	HIGH: 1st Stage 2nd Stage LOW START LOCK-UP: <u>9.2</u> PSI <u> </u> PSI START LOCK-UP: <u>12.7</u> W.C. TANK OFF: <u>6.0</u> PSI <u> </u> PSI TANK OFF: <u>9.0</u> W.C. AFTER 10 MINUTES: <u>6.0</u> PSI <u> </u> PSI AFTER 10 MINUTES: <u>9.0</u> W.C. PRESSURE AS LEFT: <u>9.0</u> PSI <u> </u> PSI PRESSURE AS LEFT: <u>11.0</u> W.C.	PIPING PRESSURE TEST				
X _____ CUSTOMER SIGNATURE	START <u>6.0</u> PSIG	FINISH <u>6.0</u> PSIG	AMOUNT RECEIVED	<u>983.05</u>		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.
Justin Sobush SERVICE REP. SIGNATURE 1/31/20 DATE [Signature] CUSTOMER SIGNATURE