

SALES  
SERVICE  
INSTALLATION



R

Mike

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 893277	Date Written 2/09/26	Taken By MEH	Schedule Date 2/10/26	Date Completed 2/10/26
Branch - Customer No. 1-10295	Home 229 291-9500	Work	Time Started 2:20	Time Completed 3:50
Name KENNY BROWN	Address 114 WOODLAND LN LEESBURG, GA	Cell	PHILEMA RD RT WHITE POND RD RT ON WOODLAND HSE ON RT cell#291-9500 (RINNAI) H/WATER ONLY	
Service Address 114 WOODLAND LN	LEESBURG, GA	31763		

Work to be performed: DELIVER AND INTSTALL RINNAI RE180eP WITH RIKF INSTALL KIT, PCD09SHS PIPE COVER, AND MC-601-W CONTROLLER. CALLED IN BY KENNY. 229-291-9500 CELL:	Work completed Removed old Rinnai Installed new Rinnai
--	--

Up ✓ Copy

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	3/4 PEX coup		3.12	1	W-R RE180 EP	7	895.00
1	3/4 PEX 90'		2.98		Extant Rinnai		
3	3/4 mpx x 3/4 PEX adp.		12.21	1	W-R RIKF	7	98.00
7	3/4 PEX rings		2.94		Ins full test		
2'	3/4 PEX PIPE.		2.-	1	W-R PCD09SHS	7	172.00
					Pipe cover		
				1	W-R MC-601-W	7	148.00
					Controller		

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 120	Serial No. 63013	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Manometer Reading Under Load	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	1352.75
Manufacturer Rinnai	Model No. RE180e	Serial No. TJ. UA-129212	Sed. Trap Vent NO YES	TRIP CHARGE	
Fuel/BTU 000	180 000	N/A	N/A	LABOR	195.-
AGE 2019	Shut off Installed YES			SUB-LABOR Rebate	<200.00>
<input type="checkbox"/> CASH <input type="checkbox"/> CHECK				PERMIT	
RECEIVED BY				SHIPPING/FREIGHT	
Work Completed by: Mike & A.J.				SALES TAX	108.22
Customer Signature: K Brown				TOTAL	1455.97

Work Completed by: Mike & A.J. Date 2/10/26

Customer Signature: K Brown Date 2/10/26

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS?  YES  NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?  YES  NO

CUSTOMER AVAILABLE  YES  NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE  YES  NO