

R

RH + CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 892001	Date Written 1-27-26	Taken By: DT	Schedule Date 2-17-26	Date Completed 2-17-26
Branch - Customer No. 1-19088	Home 706 445-7650	Work	Time Started 9:00	Time Completed 1:00
Name CONNER CONSTRUCTION CO	Address 245 CORK FERRY RD	City CORDELE, GA	State 31015	Zip
Service Address 101 SOUTHLAND RIDGE AMERICUS, GA 31709		NEW CONSTRUCTION LOT 101 SOUTHLAND RIDGE DR AMERICUS		

Work to be performed: INSTALL GAS LINE FROM METER FOR RINNAI AND GAS COOK TOP PER EST ATTACHED AND INSTALL - RINNAI RE160EP	Work completed HANG RINNAI + INSTALL GAS LINES FOR COOK TOP + RINNAI
---	---

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
	RE160EP			1	RE160EP		805.00
	TE.UA-065675			1	REKF Install Kit		98.00
	FROM WO # 891944			1	MC-601 CONTROL VALVE		139.00
	METER # M0089378			1	BRPC009-SHS PIPE COUPLER		162.00

DR. RT.	Rt. Seq.	Rate	Deposit	NG POB	395.50	
Tank Make	Size	Serial No.	Tank Percent	FROM WO # 891844		
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?
TWO 1st						
STAGE 2nd						

Manometer Reading at Start 8	Manometer Reading After 10 minutes 8	Flow Check Manometer Reading Under Load	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	1,616.07
Manufacturer Rinnai	Model No. RE160EP	Serial No. TE.UA-065675	Sed. Trap Vent	TRIP CHARGE	
Fuel/BTU 000 160 000	AGE New			LABOR 4	680.00
				SUB-LABOR Rebate	<200.00>
				PERMIT	
				SHIPPING/FREIGHT	
				Thank You	SALES TAX 129.29
					TOTAL 3,225.36

CASH RECEIVED BY
 CHECK

Work Completed by: CH-RH Date 2-17-26
 Customer Signature: [Signature] Date 2/17/26

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO
 IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO
 CUSTOMER AVAILABLE YES NO
 CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO