



INVOICE
No. 11030

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Firebreak Barriers</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>130 Lewis Ln.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Alma GA 31510</u>	DATE PROMISED	_____
PHONE	<u>912-286-5035</u>	DATE COMPLETED	<u>2-10-26</u>
LOCATION	<u>Randy + Becky Miller</u>	TERMS	_____

INSTRUCTIONS install tankless water heater

QTY	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RX199 tankless water heater w/valuation valves, RNOVC cap, serial # TJ.BA-208158		1819.95
1	Resp LV340384 second stage regulator		59.95
3'	1/2" coated copper tubing	3.49	10.47
1	1/2" cut off valve		16.95
4	1/2" flare nut	1.60	6.40
2	3/8" flare nut	2.20	4.40
1	5/8" x 1/2" tee		6.99
2	1/2" x 1/2" male adapter	3.09	6.18
All	other gas fittings, thread sealant		15.40

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	SERVICES PERFORMED	TOTAL MATERIAL	1946.69
	<u>installed tankless water heater, ran pressure check</u>		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>			
	TOTAL TIME _____ HOURS	LABOR	150.00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED	SUBTOTAL	
	BY <u>[Signature]</u>	SALES TAX	155.74
X _____		TOTAL DUE	2252.43
CUSTOMER'S SIGNATURE			

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				AMOUNT RECEIVED \$ <u>2052.43</u>
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		RECEIVED BY <u>2052.43</u>
		HIGH	LOW	
SIZE:	SIZE:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	DATE _____
S/N:	S/N:	AFTER 10 MINUTES:	AFTER 10 MINUTES:	SERVICES RECEIVED BY _____
GALLONS OR READING:	GALLONS OR READING:	PRESSURE AS LEFT:	PRESSURE AS LEFT:	

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 2/10/26
 Name Firebreak Berrias Company Sikes Propane, Inc.
 Address 130 Lewis Ln. Call Taken By _____
 City Alma State GA Zip 31510 Telephone (Cell) 912-286-5035 (Home) _____

Appliance Check

Appliance	<u>water heater</u>				
Manufacturer	<u>Rinnai</u>				
Model #	<u>RX199i</u>				
Serial #	<u>TJBA-20 8158</u>				
BTU's	<u>199,000</u>				
Burner / Com. Chamber	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>				
Venting System	<u>ok</u>				
Age	<u>new</u>				
Takes Out Of Service Or Operation					

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>96085</u>	<u>Quality Steel</u>	<u>1971</u>	<u>ok</u>	<u>ok</u>	<u>ok</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>85psi.</u>	<u>85psi.</u>	<u>10min.</u>	<input checked="" type="checkbox"/>
			Work Order <input type="checkbox"/>

Piping Check

Materials	Size	Cover / Protection
<u>copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<input checked="" type="checkbox"/>
			Work Order <input type="checkbox"/>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rago</u>	<u>02C2025/LV3403TR</u>	<u>w/c</u>
<u>Second</u>	<u>Rago</u>	<u>07E2024/LV3403B4</u>	<u>down</u>

Safety Information Supplied: _____

Comments: Please note all repairs and corrections made along with any recommended actions.