



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Randy Bryan RT# _____ RT. SEQ. _____ ACCT # 1-50232 DATE 1/26/15 INT SW

MAILING ADDRESS 238-1871 CO. _____ CITY _____
ADDRESS 2836 Hwy 32W APT/LOT NO. _____
CITY Chula STATE GA ZIP CODE 31733

NEW CUSTOMER INFORMATION	
S.S. NO.	DELV
HOME PH	RENT
WORK PH	CREDIT
LITE PILOT	PC
EMPLOYER	
DR.	USE LEASE

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

replace 9.4 with 12.7 per Eric

email: _____
cell # 229-238-1871
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Needs done as soon as possible

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	<u>250</u>	<u>231748</u>							

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Ac180c</u>	<u>TH.0A-116499</u>			<u>1199.95</u>
	<u>1/2 cutoff</u>				<u>19.95</u>
	<u>3/4 B/I misc.</u>				<u>19.95</u>
	<u>B46R</u>				<u>84.95</u>
	<u>MISC. supplies</u>				<u>19.49</u>

WORK PERFORMED: <u>installed new</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>w/h</u>	MAKE: <u>rego</u> MODEL: <u>T199</u>	PARTS/MAT. USED	<u>1199.95</u>
	DATE CODE: <u>05c2025</u> VENT: <u>Down</u>	TANK RENT	<u>124.85</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST			SALES TAX _____ %	LABOR	INVENTORY TOTAL
	HIGH: 1st Stage 2nd Stage LOW					
	START LOCK-UP: <u>9.2</u> PSI		START LOCK-UP: <u>12.7</u> W.C.		<u>200.00</u>	
	TANK OFF: PRESSURE <u>6.0</u> PSI		TANK OFF: PRESSURE <u>9.0</u> W.C.		<u>19.49</u>	
	AFTER 10 MINUTES: <u>6.0</u> PSI		AFTER 10 MINUTES: <u>9.0</u> W.C.	<u>C-PL</u>	<u>GR</u>	<u>(200.00)</u>
	PRESSURE AS LEFT: <u>9.0</u> PSI		PRESSURE AS LEFT: <u>11.0</u> W.C.			
X	PIPING PRESSURE TEST			INV. TOTAL		<u>1,472.31</u>
CUSTOMER SIGNATURE	START <u>6.0</u> PSIG	FINISH <u>6.0</u> PSIG	AMOUNT RECEIVED			

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Justin + Shown SERVICE REP. SIGNATURE 2/27/26 DATE X _____ CUSTOMER SIGNATURE