



congerlpgas.com

INVOICE / WORK ORDER NO.

113323

229-392-3731 146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

NAME Tim Ingram RT# _____ RT. SEQ. _____ ACCT # 1-18018 DATE 2/29/26

MAILING ADDRESS _____ CO. _____ CITY _____
ADDRESS 2130 Chula Brook Level Rd
CITY Chula STATE GA ZIP CODE 31794

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Service performed on 2/16/25 - Still flashing w code uLCT

email: ingramboards@gmail.com
cell # 229-392-3731
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	<u>120</u>	<u>37870</u>		<u>On Site</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Rinnai Tankless Water Heater</u> <u>REV-VC2837PFUD-US</u>	<u>RL94iF</u>	<u>MG-CA-012207</u>		<u>899.95</u>

WORK PERFORMED: <u>Replaced w/H</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	<u>899.95</u>
	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>MS</u>	<u>6.00</u>
	DATE CODE: <u>06D16</u>	VENT: <u>Down</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST			SALES TAX <u>8%</u>	LABOR <u>UB</u>	<u>100.00</u>
	HIGH:	1st Stage	2nd Stage			
	START LOCK-UP:	<u>10</u> PSI	PSI	START LOCK-UP:	W.C.	
	TANK OFF: PRESSURE	<u>7</u> PSI	PSI	TANK OFF: PRESSURE	W.C.	<u>(200.00)</u>
	AFTER 10 MINUTES: PRESSURE	<u>7</u> PSI	PSI	AFTER 10 MINUTES: PRESSURE	W.C.	
	AS LEFT:	<u>10</u> PSI	PSI	AS LEFT:	W.C.	

X _____ CUSTOMER SIGNATURE	PIPING PRESSURE TEST		INV. TOTAL	<u>694.57</u>
	START	PSIG	FINISH	PSIG
			AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.
SERVICE REP. SIGNATURE [Signature] DATE 2/29/26 CUSTOMER SIGNATURE _____