



congerlpgas.com

INVOICE / WORK ORDER NO.

119573

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Martha Hall RT# EE RT. SEQ. _____ ACCT # 1-50975 DATE 11/21/25 INT Am

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 3012 Hall Whitley Rd APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31793

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: CAC12003@yahoo.com

cell # 229-402-0464

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Run Line for cooktop, purchase & install
Rinnai

DIRECTIONS:

Craig Castleberry
(son)

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>Set</u>	<u>120</u>	<u>1562074</u>							
<u>misc supplies</u>									<u>63 15</u>

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Be180ep</u>	<u>Be180e</u>	<u>THUA-116506</u>		<u>1199.95</u>
<u>15'</u>	<u>1/2 copper</u>			<u>4.95</u>	<u>74.24</u>
<u>46'</u>	<u>1/2 trac</u>			<u>5.95</u>	<u>273.70</u>
<u>2</u>	<u>1/2 trac straight fittings</u>			<u>39.95</u>	<u>79.90</u>
<u>2</u>	<u>1/2 endoff valves</u>			<u>24.95</u>	<u>49.90</u>
<u>1</u>	<u>BYGR</u>				<u>84.95</u>
<u>2</u>	<u>1/2 flare nuts</u>			<u>2.95</u>	<u>5.90</u>
<u>1</u>	<u>1/2 mip</u>				<u>3.95</u>
	<u>misc BE</u>				<u>30.00</u>

WORK PERFORMED: <u>Set tank, installed</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	<u>1199.95</u>
<u>Water heater, and cooktop</u>	MAKE: <u>Rinnai</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED		<u>602.54</u>
	DATE CODE: <u>050225</u>	VENT: <u>Down</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX	<u>18.95</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH:	1st Stage	2nd Stage	LOW	%	<u>108.00</u>
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP:	<u>10.0</u> PSI		<u>12.7</u> w.c.	LABOR	<u>542.3</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF PRESSURE:	<u>6.0</u> PSI		<u>9.0</u> w.c.		<u>1.71</u>
	AFTER 10 MINUTES:	<u>6.0</u> PSI		<u>9.0</u> w.c.		<u>5.68</u>
	PRESSURE AS LEFT:	<u>9.0</u> PSI		<u>11.0</u> w.c.		<u>450.00</u>
	PIPING PRESSURE TEST			INV. TOTAL		<u>6.315</u>
	START	<u>6.0</u> PSIG	FINISH	<u>6.0</u> PSIG		<u>(200.00)</u>
	AMOUNT RECEIVED					<u>2304.21</u>

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Joshua Seaborn SERVICE REP. SIGNATURE 3-18-2026 DATE _____ CUSTOMER SIGNATURE