



congerlpgas.com

115304

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W. Valdosta, GA 31602 (229) 469-4250

NAME Bruce Blount RT# _____ RT. SEQ. _____ ACCT # 7-14858 DATE 2-9-26 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 621 Chastain St. APT/LOT NO. _____

CITY Vidalia STATE GA ZIP CODE _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

st Run lines for WHA & Grill.

email: ~~912 536 5074~~
cell # 912 536 5074

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>120</u>	<u>152842050</u>	<u>50</u>	<u>on site</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	1/2 riser			74.95	74.95
1	1/2 Tee			109.95	109.95
2	Transition 1/2			59.95	119.90
2	coupling 1/2			34.95	69.90
8	nut/plug			2.95	23.60
3	Br fittings			3.95	11.85
1	gpd 20lb			29.95	29.95
1	666			84.95	84.95
1	Sec Trap			79.00	79.00

WORK PERFORMED: Run line to WHA REGULATION INFORMATION MAKE: Regco MODEL: T19 APPLIANCES/EQUIP. SOLD CODE: WHA 1099.95 8.
& gpd for grill. No leak DATE CODE: 0912024 VENT: Down PARTS/MAT. USED 619.00 4.
in system. TANK RENT 10.00 1.
 SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE Comp 18.95 1.

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	LEAK AND PRESSURE TEST			SALES TAX 8% 173.38	
	HIGH:	1st Stage	2nd Stage		LOW
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP:	10 PSI	PSI	START LOCK-UP:	W.C. LABOR 360.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF PRESSURE:	9 PSI	PSI	TANK OFF PRESSURE:	W.C. MS 58.74
	AFTER 10 MINUTES PRESSURE AS LEFT:	5 PSI	PSI	AFTER 10 MINUTES PRESSURE AS LEFT:	W.C. Gas 60.00 161.94 12
		10 PSI	PSI		W.C. Trenches 150.00 1

PIPING PRESSURE TEST INV. TOTAL 2648.08

CUSTOMER SIGNATURE _____ START _____ PSIG FINISH _____ PSIG AMOUNT RECEIVED _____

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE. gr-(200.00)

Jackson Hartley SERVICE REP. SIGNATURE 3-3-26 DATE x CUSTOMER SIGNATURE

