

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: CODY BOSTIC
117 BURTON RD
FITZGERALD, GA 31750

INVOICE NO: 56782
DATE: 2/25/26

CUSTOMER NO: 3758/3834

TYPE: RO - RESIDENTIAL COUNTY BenHil

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SER # TH UA 119756 Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	1,019.50	1,019.50
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	175.73	175.73
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	63.80	63.80
1.00	Sales Tax	100.72	100.72

TOTAL DUE: \$1,359.75

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 2/25/26 DUE DATE: 3/09/26
CUSTOMER NO: 3758/3834

NAME: BOSTIC, CODY
TYPE: RO - RESIDENTIAL COUNTY BenHil

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD GA 31750

INVOICE NO: 56782
TERMS: NET 10 DAYS

AMOUNT:

GA
Rebate
\$1,359.75
- 200.00
\$1,159.75

Account Number 3758
 Name Cody Bostick
 Address 117 Buckaw Rd
Fitz, GA

Call Date: 2/25/26 Date Requested: 3/2/26
 Instructions: set tank / mount tankless water heater

Telephone Office: _____ Home: _____

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6
Manufacturer			Rinnai			
Model No.			RE180e			
Serial No.			TH-UA-119756			
Location			Exterior			
BTU	000	000	180 000	N/A	N/A	000 000
Age			New			
Manual Shutoff (Installed/Existing)			installed			
Venting			gd			

TANK/CYLINDER 1764

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test	
											Cond.	Date	Cap		
120	U-239851	CYLSA	2025	1/11/26	Exterior	new	new	new	new	new	new	new	new	new	5 min

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE/ CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
TWO STAGE	Copper	1/2	03/24	New	Rego	LV404B4	Level	Done	11 IN. WC

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
TWO STAGE	11 (Inches W.C.)	11 (Inches W.C.)	5 min	✓ OK

Comments: _____

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. WF0535416 Date 3/2/26
 (Mo. Day Yr.)

I, Cody Bostick
 (Please Print)

I, Chris Woods
 (Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

Certify that I have completed the System Check as prescribed

Performed Odor Test Yes Performed Pressure Test Yes
 Left Consumer Safety Info Yes

Chris Woods

Cody Bostick