

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: CUSTOM YARD POWER & EQUIPMENT
2125 GA HWY 32 W
OCILLA, GA 31774

INVOICE NO: 56780
DATE: 2/25/26

CUSTOMER NO: 3047/3130

TYPE: RR - Residential Irwin Co

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SER# TH UA 119759 Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	1,112.18	1,112.18
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	191.70	191.70
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	69.60	69.60
1.00	Sales Tax	109.88	109.88
1.00	Tank Lease TANK LEASE	60.00	60.00

TOTAL DUE: \$1,543.36

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 2/25/26 DUE DATE: 3/09/26
CUSTOMER NO: 3047/3130

NAME: CUSTOM YARD POWER & EQUIPMENT
TYPE: RR - Residential Irwin Co

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD GA 31750

INVOICE NO: 56780
TERMS: NET 10 DAYS

AMOUNT:

GA
Rebate

\$1,543.36
- 200.00
<u>\$1,343.36</u>

FITZGERALD UTILITIES

PROPANE SAFETY CHECK FOR RESIDENTIAL CUSTOMERS

No 002970

Account Number 3047
 Name Custom Yard
 Address 1918 Frank Rd
Fitz, GA

Call Date: 2/25/26 Date Requested: 3/10/26
 Instructions: set tank / no vent tankless water heater

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6
Manufacturer			<u>Rinnai</u>			
Model No.			<u>RE180e</u>			
Serial No.			<u>TH,UA-119759</u>			
Location			<u>Exterior</u>			
BTU	000	000	<u>180</u> 000	N/A	N/A	000 000
Age			<u>New</u>			
Manual Shutoff (Installed/Existing)			<u>installed</u>			
Venting			<u>gd</u>			

TANK/CYLINDER 153W

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test
											Cond.	Date	Cap	
<u>120</u>	<u>1945220</u>	<u>Worthington</u>	<u>2020</u>	<u>1/11/26</u>	<u>Exterior</u>	<u>New</u>	<u>New</u>	<u>New</u>	<u>New</u>	<u>New</u>				<u>Spin</u>

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
TWO STAGE	<u>Copper</u>	<u>1/2</u>	<u>03/24</u>	<u>New</u>	<u>Rupp</u>	<u>1040434</u>	<u>Level</u>	<u>Pipe</u>	<u>11</u> IN. WC

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure (Inches W.C.)	End Pressure (Inches W.C.)	Time Held	System OK
	<u>11</u>	<u>11</u>	<u>5min</u>	<u>OK</u>

Comments: _____

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

I, Blake Lotz (Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

Blake Lotz

Reference Invoice No. WFO555416 Date 3/10/26 (Mo. Day Yr.)

I, Chris Woods (Please Print)

Certify that I have completed the System Check as prescribed

Performed Odor Test Yes Performed Pressure Test Yes
 Left Consumer Safety Info Yes

Chris Woods