



INVOICE

No 11306

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515  
 2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Binky Williams @ Migrant House</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>533 Hemington Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Hazlehurst, Ga 31539</u>	DATE PROMISED	_____
PHONE	<u>1-334-606-0719</u>	DATE COMPLETED	<u>2-19-26</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS set 250 gallon tank, run gas lines, install two tankless water heaters + 10 gas cooktops

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
200	<u>gallon of propane</u>	1 49	298 00
2	<u>Rinnai RE199ep tankless water heater w/iso valves, s# TJ.4A-142746, #TF.4A-087288</u>	1500 00	3000 00
10	<u>30" Deli-Kit gas cooktop</u>	300 00	3000 00
69'	<u>1/2" coated copper tubing</u>	3 49	240 81
1	<u>Rogo LV4403B66 second stage regulator</u>		69 95
3	<u>1/2" cut off valve</u>	16 95	50 85
45	<u>1/2" flare nut</u>	1 60	72 00
5	<u>1/2" swivel</u>	3 99	19 95
All	<u>other gas fittings, thread sealant, per fittings</u>		141 80

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	SERVICES PERFORMED	TOTAL MATERIAL	6893 36
	<u>set 250 gallon tank, run all gas lines, installed two tankless water heaters + 10 gas cooktops, converted cooktops to LP, ran pressure check, lit + checked out appliances</u>		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>		TOTAL TIME _____ HOURS	LABOR 1100 00
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>			

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED	SUBTOTAL	
X _____	BY <u>Daniel Williams</u>	SALES TAX	
CUSTOMER'S SIGNATURE		TOTAL DUE	7993 36

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-6 PPA rebate 400.00 AMOUNT \$ 7593.36
LEAK AND PRESSURE TEST				
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	HIGH	LOW	RECEIVED BY _____ DATE _____ SERVICES RECEIVED BY _____
SIZE:	SIZE:	START LOCK UP:	START LOCK UP:	
SN:	SN:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	
GALLONS OR READING:	GALLONS OR READING:	AFTER 30 MINUTES:	AFTER 30 MINUTES:	
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

# GASCheck - Gas Appliance System Check

Account Name @ Migrant House Invoice Number \_\_\_\_\_ Date 2/19/26  
 Name Binky Williams Company Sikes Propane, Inc.  
 Address \_\_\_\_\_ Call Taken By \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_ Telephone (Cell) 334-606-0719 (Home) \_\_\_\_\_

## Appliance Check

Appliance	<u>water heater</u>	<u>water heater</u>				
Manufacturer	<u>Rinnai</u>	<u>Rinnai</u>				
Model #	<u>RE199ap</u>	<u>RE199ap</u>				
Serial #	<u>TJ.4A-14 2746</u>	<u>TF.4A-08 7288</u>				
BTU's	<u>199,000</u>	<u>199,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

## Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1554007</u>	<u>Quality Steel</u>	<u>2025</u>	<u>ok</u>	<u>new</u>	<u>02C23</u>	<u>ok</u>

## Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>95psi.</u>	<u>95psi.</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

## Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

## System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

## Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rago</u>	<u>05C2025 / LV4403TR9</u>	<u>n-c</u>
<u>Second</u>	<u>Rago</u>	<u>08B2024 / LV4403B66</u>	<u>down</u>

## Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.