

- SALES
- SERVICE
- INSTALLATION



Royce & AJ

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 893235	Date Written 2-24-26	Taken By: MEH	Schedule Date 2/24/26	Date Completed 2/24/26
Branch - Customer No. 1-19213	Home 229 405-9456	Work	Time Started 9:30	Time Completed 5:00
Name KALMAN & CO.	Address 2901 S LYNNHAVEN RD #340	City VIRGINIA BEACH, VA	State VA	Zip 23452-8505
Service Address 1315 W OAKRIDGE DR	ALBANY, GA	31707-5361		

Work to be performed: DELIVER AND INSTALL (2) RINNAI CX199IN WITH (2) RIKF INSTALL KITS, (2) RXOVC OUTDOOR VENT CAPS, (2) PCD11-IB BLACK PIPE COVERS. CALLED IN BY MATT. 229-405-9456 OR 229-881-1980 CELL:

Work completed: Delivered and installed

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	CX199IN # TJ, BA-210313			2	W-R CX199IN/P Rinnai Commercial Unit	1653.00	3306.00
1	CX199IN # TJ BA 210321			2	W-R RIKF Install kits	98.00	196.00
				2	W-R RXOVC Outdoor Vent Cap	48.00	96.00
				2	W-R PCD11-IB Pipe cover	198.00	396.00
				1	W-R MCC-601W Commercial Controller		201.00
				1	Cascade Cable		64.00

Manometer Reading at Start 2	Manometer Reading After 10 minutes 2	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	4275.50
Manufacturer Rinnai	Model No. CX199IN/P	Serial No. TJ, BA-210313	Water heater Rinnai CX199IN/P	TRIP CHARGE	
Sed. Trap Vent				LABOR	
Fuel/BTU 000	199 000	N/A	N/A	SUB-LABOR Rebate	<400.00
AGE New				PERMIT	
Shut off Installed 4				SHIPPING/FREIGHT	
<input type="checkbox"/> CASH <input type="checkbox"/> CHECK				Thank You	SALES TAX 342.04
RECEIVED BY				TOTAL	4217.54

Work Completed by: Royce AS Date: 2/24/26

Customer Signature: [Signature] Date: 2/24/26

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO

CUSTOMER AVAILABLE YES NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO