

*Mike*

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 893330	Date Written 2/24/26	Taken By: MEH	Schedule Date 2/26/26	Date 2/26/26
Branch - Customer No. 1-91428	Home 229 591-9611	Work	Time Started 10:30	Time Completed 2:15
Name WILLMAR PLANTATION #3	Address LODGE ( ROBERT PRYOR )	Cell	HWY 195 GO 10 MI LFT ON BATTS RD PST WHITE CHURCH LFT MAYS RD RT PINEY GRV RT USRY RD DRIVE ON RT 2-RINNAI W/H, HEAT, COOK	
City ST SIMONS Island	State GA	Zip 31522-2490		
Service Address 1088 USRY RD	SMITHVILLE, GA	31787-2826		

Work to be performed:  
DELIVER AND INSTALL (2) RE180eP WITH (2) INSTALL KITS, (2) PCD09-SHS PIPE COVERS, MC-601-W CONTROLLERS. CALLED IN BY TOMMY ROBERT PRYOR TO GET IN. 229-591-9611 CELL

Work completed  
Removed 2 Rinnai W/H  
AND (2) Installed 2 Rinnai W/H.  
CALL did not install controllers cause did not answer phone.

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
6	3/4 mid x 3/4 PEX adp		24.42	2	W-R RE180EP	895.00	1790.00
2	3/4 PEX 90		5.96		Enter for Dr-pipe		
3	3/4 PEX coup		9.36	2	W-R PIKF	98.00	196.00
2'	3/4 PEX pipe		2.-		Inst full kit		
14	3/4 PEX rings		5.88	2	W-R PCD09SHS	172.00	344.00
	Up ✓ Copy			2	Pipe covers		
				2	W-R MC-601-W	148.00	296.00
					Controllers		

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 330	Serial No. N9353CH	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr.
TWO 1st			Model
STAGE 2nd			Vent Pos.
			Protected?

Manometer Reading at Start 10	Less Check Manometer Reading After 10 minutes 10	Flow Check Manometer Reading Under Load water heater	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	2690.12
Manufacturer Rinnai	Rinnai			TRIP CHARGE	
Model No. RE180eP	RE180eP			LABOR	
Serial No. TLUA-161563	WR-UA-010395			SUB-LABOR Rebate	<400.00>
Sed. Trap NO	YES	NO	YES	PERMIT	
Fuel/BTU 000	180,000	180,000	N/A	SHIPPING/FREIGHT	
AGE 2019	2019			Thank You	SALES TAX 215.21
Shut off Installed Yes	Yes	Yes		TOTAL	2505.33

RECEIVED BY: *Mike* Date: 2/26/26

Customer Signature: *[Signature]* Date: 2-26-26

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS?  YES  NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?  YES  NO

CUSTOMER AVAILABLE  YES  NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE  YES  NO