

R

RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number <b>893446</b>	Date Written <b>3/2/26</b>	Taken By <b>MEH</b>	Schedule Date <b>3/05/26</b>	Date Completed <b>3-5-2026</b>
Branch - Customer No. <b>1-91645</b>	Home <b>229 344-3795</b>	Work	Time Started <b>10:00</b>	Time Completed <b>4:30</b>
Name <b>BOBBY WILSON</b>	Address <b>BOBBY &amp; WENDY WILSON</b>		Cell	
City <b>ALBANY, GA</b>	State	Zip <b>31708-1508</b>		
Service Address <b>232 FLINTVIEW DR CORDELE, GA 31015-9532</b>				

Work to be performed: DELIVER AND INSTALL RINNAI RE180iP WITH RIKF INSTALL KIT AND 223181 HORIZONTAL VENT KIT. CALLED IN BY BOBBY. 229-344-3795 CELL:

Work completed: **Delivered and installed**

Qty	Materials	Price	Amount	Qty	Materials	Price	Amount
	RE180i			1	W-H RE180iP		876.00
	Tm.VA-172082			1	W-R RIKF		98.00
				1	W-R 223181		105.00
					21" Horizontal Vent kit		
					1 MC-101 Controller		
					1 W-R-224052 19.5 VENT		55.-

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 500	Serial No.	Tank Percent
CUST OWNED			
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

Manometer Reading at Start <b>.5 psi</b>	Manometer Reading After 10 minutes <b>.5 psi</b>	Flow Check Manometer Reading Under Load <b>1.5 psi</b>	Lock-up Check Manometer Reading <b>2 psi</b>	SHOP OR TRUCK SUPPLIES	<b>16.50</b>
				MATERIAL TOTAL	<b>1150.50</b>

Manufacturer	Rinnai	Model No.	RE180iP	Serial No.	Tm.VA-172082	Sed. Trap	Y	Fuel/BTU	000 180 000	AGE	New
				SUB- <del>LABOR</del> Rebate		<b>&lt;200.00&gt;</b>					
				SALES TAX		<b>92.04</b>					
				TOTAL		<b>1042.54</b>					

RECEIVED BY **Curtis Royce** Date **3-5-2026**

Customer Signature **[Signature]** Date **3-5-26**

ANY UNUSED GAS PIPING OUTLETS INDOORS?  YES  NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?  YES  NO

CUSTOMER AVAILABLE  YES  NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE  YES  NO

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY