



INVOICE

No 11330 ✓✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Luka White</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>49 Zorbella Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	_____
PHONE	<u>912-339-3527</u>	DATE COMPLETED	<u>3-27-26</u>
LOCATION	<u>Metal building</u>	TERMS	_____

INSTRUCTIONS set 120 gallon tank, install tankless water heater

QTY	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	<u>Rinnai RE140e tankless water heater w/isolation valves, serial # TLUA-168085</u>		<u>1050 00</u>
100	<u>gallon of propane</u>	<u>2 89</u>	<u>289 00</u>
20'	<u>1/2" coated copper tubing</u>	<u>3 49</u>	<u>69 80</u>
2	<u>1/2" flare nut</u>	<u>1 60</u>	<u>3 20</u>
1	<u>1/2" cut off valve</u>		<u>16 95</u>
1	<u>1/2" swivel</u>		<u>3 99</u>
1	<u>1/2" x 3/4" female adaptor</u>		<u>3 19</u>
All	<u>Pex fittings, thread sealant, screws</u>		<u>9 00</u>

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>set 120 gallon tank, installed tankless water heater, ran gas lines, ran pressure check</u>	TOTAL MATERIAL	<u>1445 13</u>
	TOTAL TIME _____ HOURS		LABOR

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>Daniel Sikes</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	<u>115 61</u>
		TOTAL DUE	<u>1740 74</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-GPGA rebate 200.00 AMOUNT <u>1540.74</u>
INSTALLATION OR TURN ON <input checked="" type="checkbox"/>	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		
SIZE: <u>120</u>	SIZE:	HIGH	LOW	RECEIVED BY _____ DATE _____ SERVICES RECEIVED BY _____
S/N: <u>25A022993</u>	S/N:	START LOCK UP:	START LOCK UP:	
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	
		AFTER 10 MIN/TEST:	AFTER 10 MINUTES:	
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 3/27/26
 Name Luke White Company Sikes Propane, Inc.
 Address 49 Zoarballa Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-339-3527 (Home) _____

Appliance Check @ metal building

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnai</u>					
Model #	<u>RE140a</u>					
Serial #	<u>TLUA-16 8085</u>					
BTL's	<u>140,000</u>					
Burner / Com. Chamber	<u>ok</u>					
Man. Shutoff / Sed. Trap	<u>installed</u>					
Control / Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Takes Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>25A022993</u>	<u>American W.</u>	<u>1995</u>	<u>ok</u>	<u>ok</u>	<u>8B95</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	<u>0</u>
<u>100psi.</u>	<u>100psi.</u>	<u>10min.</u>	Work Order	<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	<u>0</u>
<u>9in. wc</u>	<u>9in. wc</u>	<u>10min.</u>	Work Order	<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position/ Protection
<u>Twin</u>	<u>Rego</u>	<u>02C2025/LV404B39</u>	<u>u-c</u>

Safety Information Supplied: _____

Comments: Please note all repairs and corrections made along with any recommended actions.