

● SERVICE  
● INSTALLATION

R



ENERGY FOR EVERYONE  
propane

1-5 Call

Mik

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number <b>894818</b>	Date Written 3/26/26	Taken By: MEH	Schedule Date 3/27/26	Date Completed 3/27/26
Branch - Customer No. 1-73979	Home 229 343-1587	Work	Time Started 9:45	Time Completed 11:30
Name <b>John Senkbeil</b>	Address 606 PARTRIDGE DR ALBANY, GA 31707	Cell		
Service Address 2705 BRITTANY ROAD 3ALBANY, GA 31721-1501				

Work to be performed:  
INSTALL RE160eP WITH RIKF INSTALL KIT, PCD09SHS PIPE COVER AND USED MC-91 CONTROLLER. CALLED IN BY JOHN. 229-343-1587 CELL:

Work completed  
Removed old Rinnai, Installed new Rinnai unfilled tank, pressure tested, left tank on per customer.

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
3	3/4 mtr x 3/4 pex adp	4.07	12.21	1	W-R RE160EP		195.00
2	3/4 pex coup	3.12	6.24		Rinnai water HTR		
7	3/4 pex rings	.42	2.94	1	W-R RIKF		98.00
3'	3/4 pex pipe	1.00	3.00	1	Install kit		
				1	W-R PCD09SHS		172.00
					Pipe cover		

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size	Serial No. 064469	Tank Percent 48%
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
	D.K	D.K	Rego LU401023 Hor Yes
TWO 1st			
STAGE 2nd			

Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	1105.89
Manufacturer	Rinnai			TRIP CHARGE	
Model No.	RE160e			LABOR	195.00
Serial No.	WB-HA-012034			SUB-LABOR	
Sed. Trap	NO	YES		PERMIT - Rebate	<200.00>
Fuel/BTU	000	1160	000	SHIPPING/FREIGHT	
AGE	2019	N/A	N/A	Thank You	
Shut off Installed	Yes			SALES TAX	88.47
<input type="checkbox"/> CASH <input type="checkbox"/> CHECK				TOTAL	1189.36

RECEIVED BY  
Work Completed by: Mike & AJ Date: 3/27/26  
Customer Signature: [Signature] Date: 3/27/26

ANY UNUSED GAS PIPING OUTLETS INDOORS?  YES  NO  
IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?  YES  NO  
CUSTOMER AVAILABLE  YES  NO  
CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE  YES  NO

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY