



congerlpgas.com

115367

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Robert Sewell RT# RT. SEQ. ACCT # 7-14259 DATE 3-20-26 INT

MAILING ADDRESS CO. CITY

ADDRESS 1695 Petross Rd. APT/LOT NO.

CITY Ailey STATE GA ZIP CODE 30410

NEW CUSTOMER INFORMATION S.S. NO. DELV HOME PH RENT WORK PH CREDIT LITE PILOT PC EMPLOYER DR. USE LEASE

SERVICE REQUESTED: [ ] CASH [ ] CHARGE DATE PROMISED

Hook up w/H

email: cell # 229 548 1967 PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Table with columns: TANK PICKUP/SET, TANK SIZE, SERIAL #, TANK %, TANK DESTINATION, DOT PERMANENTLY INSTALLED CONTAINERS (MANUFACTURED DATE, LAST TEST DATE, SIZE, SERIAL #, % FULL)

Table with columns: QTY, APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED, MODEL #, SERIAL NUMBER, UNIT PRICE, SALES AMOUNT

WORK PERFORMED: Hungry for wire to connect to existing system. NO Leaks REGULATION INFORMATION MAKE: Rego MODEL: TF96 DATE CODE: 06-2019 VENT: Down APPLIANCES/EQUIP. SOLD CODE 999 95 8 PARTS/MAT. USED 310 55 2 TANK RENT COMP 18 95 1

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE LEAK AND PRESSURE TEST HIGH: 1st Stage 2nd Stage LOW START LOCK-UP: 10 PSI PSI START LOCK-UP: W.C. LABOR 200 00 TANK OFF: 4 PSI PSI TANK OFF: PRESSURE W.C. MS 30 63 2 AFTER 10 MINUTES: 7 PSI PSI AFTER 10 MINUTES: W.C. WR (200 00) PRESSURE AS LEFT: 10 PSI PSI PRESSURE AS LEFT: W.C. PIPING PRESSURE TEST INV. TOTAL 1668.89 START PSIG FINISH PSIG AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE. J. Jackson HARTLEY SERVICE REP. SIGNATURE DATE 3-31-26 CUSTOMER SIGNATURE