



congerlpgas.com

115363

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Brandon Chubb RT# _____ RT. SEQ. _____ ACCT # 7-18488 DATE 3-19-26 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 1324 George Hill Rd APT/LOT NO. _____

CITY Lyons STATE GA ZIP CODE 30436

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
 HOME PH _____ RENT _____
 WORK PH _____ CREDIT _____
 LITE PILOT _____ PC _____
 EMPLOYER _____
 DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Set tank & hook up w/it

email: _____
cell # 912 805 0618
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>120</u>	<u>B7815</u>	<u>8%</u>	<u>On Site</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Regulator w/it</u>	<u>RE160eP</u>	<u>1WB-UA-012005</u>	<u>1099.95</u>	<u>1099.95</u>
<u>1</u>	<u>Sediment trap</u>			<u>75.00</u>	<u>75.00</u>
<u>1</u>	<u>Cursor</u>			<u>24.95</u>	<u>24.95</u>
<u>1</u>	<u>3/4 straight line fitting</u>			<u>44.95</u>	<u>44.95</u>
<u>4</u>	<u>nut/flare nut</u>			<u>2.95</u>	<u>11.80</u>
<u>2</u>	<u>1/2 copper</u>			<u>5.75</u>	<u>11.90</u>

WORK PERFORMED: Tank set, hookup.

Convert store. Gas check ok

No leaks in system.

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

REGULATION INFORMATION

MAKE: Reps MODEL: Y9

DATE CODE: 0102024 VENT: Down

APPLIANCES/EQUIP. SOLD: 1099.95

PARTS/MAT. USED: 168.60

TANK RENT: 10.00

SALES TAX: 18.95

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	<u>2</u> PSI	PSI	START LOCK-UP: W.C.
TANK OFF: PRESSURE	<u>1</u> PSI	PSI	TANK OFF: PRESSURE W.C. <u>MS</u>
AFTER 10 MINUTES: PRESSURE	<u>1</u> PSI	PSI	AFTER 10 MINUTES: W.C. <u>GR</u>
PRESSURE AS LEFT:	<u>2</u> PSI	PSI	PRESSURE AS LEFT: W.C. <u>Gas</u>

LABOR: 360.00

INVENTORY: MS

GR: (200.00)

Gas: 9.6gal

INV. TOTAL: 1828.22

AMOUNT RECEIVED: _____

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature] SERVICE REP. SIGNATURE

3/26/26 DATE

[Signature] CUSTOMER SIGNATURE