

INSTALLATION



1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 894312	Date Written 3/30/26	Taken By WN <i>MEM</i>	Schedule Date 4/2/26	Date Completed 4/2/26
Branch - Customer No. 1-11801	Home 229 886-1212	Work	Time Started 2:16	Time Completed 5:34
Name TIM COLEY BUILDER #08	Address JOE & JILL CARROLL J 3/26	City LEESBURG, GA 31763	LAST HERE PATRICK & LISA WILLIAMS JOB 2613 FOX HOLLOW 2025	
Service Address 100 HAZELWOOD DRIVE LEESBURG, GA 31763				

Work to be performed: Run gas line for Rinnai #RX180iN-SENSEI MIVK-T-LW Install Kit, 184162PP-Con Roof 189958 Flashing, 224080PP-Vent Pipe Extens., fireplace, range, generator, grill stub. by Steven and Jill 854-1203 Wall Switch	Work completed <i>Rangas to Rinnai and vented Rinnai, Dischar, Rinnai - Called in for Logs.</i>
---	--

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
2	90° Elbow #224078PP	34.-	68.-	①	WR-RX180iN Sensei Rinnai R/K/F		1290.00
1	39" 1" #224080PP		42.-	①	WR- [REDACTED] Install Kit		98.00
1	19 1/2" #224079PP		35.-	①	WR-184162PP-Con Roof Dis		79.00
				①	WR-189958-Flashing		21.00

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size	Serial No.	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr.
TWO 1st			
STAGE 2nd	TG. BA 150686		

Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Flow Check Manometer Reading Under Load	Lock-up Check Manometer Reading
Central Heating	Water Heater	Range	Clothes Dryer
Manufacturer Rinnai	Model No. RX180iN	Serial No. TG. BA-150686	
Sed. Trap	Vent	Fuel/BTU 000	AGE New
Shut off Installed			

SHOP OR TRUCK SUPPLIES	16.50
MATERIAL TOTAL	1699.50
TRIP CHARGE	
LABOR	170.00
SUB-LABOR Rebate	<200.00
PERMIT	
SHIPPING/FREIGHT	
Thank You	SALES TAX
	TOTAL
	1805.46

RECEIVED BY *Ty & Ryan* Date 4/2/26

Customer Signature *[Signature]* Date 4/2/26

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO

CUSTOMER AVAILABLE YES NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO