



INVOICE

No 11349 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515  
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

|                |                        |                |                |
|----------------|------------------------|----------------|----------------|
| NAME           | <u>Kandace Ogwin</u>   | ACCOUNT NO.    | _____          |
| MAIL ADDRESS   | <u>1159 Azalea Rd.</u> | DATE ORDERED   | _____          |
| CITY/STATE/ZIP | <u>Baxley GA 31513</u> | DATE PROMISED  | _____          |
| PHONE          | <u>912-278-5796</u>    | DATE COMPLETED | <u>4-22-26</u> |
| LOCATION       | _____                  | TERMS          | _____          |

INSTRUCTIONS install tankless water heater, run gas line

| QTY. | TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL  | UNIT PRICE   | SALES AMOUNT   |
|------|--|--------------|----------------|
| 1    | <u>Rinnai RE199e tankless water heater w/ isolation valves, serial # TL4A-164967</u> |              | <u>1500 00</u> |
| 230' | <u>1/2" poly pipe w/ metal detecting tape</u>  | <u>85</u>    | <u>195 50</u>  |
| 2    | <u>3/6" X-riser</u>  | <u>64 95</u> | <u>129 90</u>  |
| 1    | <u>Rego LV3403B4 second stage regulator</u>  |              | <u>59 95</u>   |
| 1    | <u>1/2" cut off valve</u>  |              | <u>16 95</u>   |
| All  | <u>other gas fittings, thread sealant</u>  |              | <u>47 20</u>   |
| All  | <u>water pipe, pex fittings, rings</u>   |              | <u>59 28</u>   |
| All  | <u>power wire, wire connectors</u>   |              | <u>29 00</u>   |
| 1    | <u>Trencher rental</u>   |              | <u>150 00</u>  |

|   |  |                |                |
|---|--|----------------|----------------|
| SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:<br><br>1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/><br><br>2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/> | SERVICES PERFORMED <u>run gas line from generator to tankless water heater, installed tankless wh, took out old water heater, ran pressure check, lit &amp; checked out water heater</u> | TOTAL MATERIAL | <u>2187 78</u> |
|   | TOTAL TIME _____ HOURS   | LABOR          | <u>1200 00</u> |

|   |   |           |                |
|---|---|-----------|----------------|
| THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.<br><br>X _____<br>CUSTOMER'S SIGNATURE | SERVICES PERFORMED BY <u>Daniel Sikes</u> | SUBTOTAL  |                |
|   |   | SALES TAX | <u>175 02</u>  |
|   |   | TOTAL DUE | <u>3562 80</u> |

|   |                     |                   |                   |   |
|---|---------------------|-------------------|-------------------|---|
| SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE |                     |                   |                   | -GPGA rebate 200.00 ✓<br>AMOUNT \$ <u>3,362.80</u>            |
| LEAK AND PRESSURE TEST  |                     |                   |                   |   |
| INSTALLATION OR TURN ON   | REMOVAL OR TURN OFF | HIGH              | LOW               | RECEIVED BY _____<br>DATE _____<br>SERVICES RECEIVED BY _____ |
| SIZE:   | SIZE                | START LOCK UP     | START JACK UP     |   |
| S/N:  | S/N:                | TANK OFF PRESSURE | TANK OFF PRESSURE |   |
| GALLONS OR READING:   | GALLONS OR READING: | AFTER 10 MINUTES  | AFTER 10 MINUTES  |   |
|   |                     | PRESSURE AS LEFT: | PRESSURE AS LEFT: |   |

# GASCheck - Gas Appliance System Check

Account Name \_\_\_\_\_ Invoice Number \_\_\_\_\_ Date 4/22/26  
 Name Kandace Ogum Company Sikes Propane, Inc.  
 Address 1159 Azalea Rd. Call Taken By \_\_\_\_\_  
 City Baxley State GA Zip 31513 Telephone (Cell) 912-278-5796 (Home) \_\_\_\_\_

## Appliance Check

|                                   |                |                  |  |  |  |  |
|-----------------------------------|----------------|------------------|--|--|--|--|
| Appliance                         | Generator      | water heater     |  |  |  |  |
| Manufacturer                      | Generac        | Rinnai           |  |  |  |  |
| Model #                           | G0070433       | RE199e           |  |  |  |  |
| Serial #                          | 30117396<br>49 | TL-4A-16<br>4967 |  |  |  |  |
| BTL's                             | 355,000        | 199,000          |  |  |  |  |
| Burner - Comb. Chamber            | ok             | ok               |  |  |  |  |
| Man. Shutoff - Sed. Trap          | existing       | installed        |  |  |  |  |
| Control - Pilot Safety System     | ok             | ok               |  |  |  |  |
| Venting System                    | ok             | ok               |  |  |  |  |
| Age                               | 2yrs.          | new              |  |  |  |  |
| Taken Out Of Service Or Operation |                |                  |  |  |  |  |

## Container Check

| Size | Serial # | Manufacturer  | MFR. Date | Location | Container Condition | Relief Valve | Fittings Leak Check |
|------|----------|---------------|-----------|----------|---------------------|--------------|---------------------|
| 250  | 1522088  | Quality Steel | 2024      | ok       | ok                  | 07E23        | ok                  |
|      |          |               |           |          |                     |              |                     |
|      |          |               |           |          |                     |              |                     |

## Pressure Test (If Applicable)

| Start Pressure | End Pressure | Time Held | Pressure Held |
|----------------|--------------|-----------|---------------|
| 125psi         | 125psi       | 10min.    | 0             |
|                |              |           | Work Order 0  |

## Piping Check

| Materials     | Size     | Cover / Protection |
|---------------|----------|--------------------|
| coated copper | 1/2"     | ok                 |
| poly          | 1/2" CTS | ok                 |
|               |          |                    |

## System Leak Check

| Start Pressure | End Pressure | Time Held | Pressure Held |
|----------------|--------------|-----------|---------------|
| 9in.wc.        | 9in.wc.      | 10min.    | 0             |
|                |              |           | Work Order 0  |

## Regulator Check

| Type   | Manufacturer | Date / Model         | Vent Position / Protection |
|--------|--------------|----------------------|----------------------------|
| First  | Rego         | 06D2024 / LV4403TR9  | u-c                        |
| Second | Rego         | 04B2024 / LV4403B66R | down                       |
| Second | Rego         | 04C2025 / LV3403B4   | down                       |

## Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.