

R

RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 894207	Date Written 4/14/26	Taken By MEH	Schedule Date 4/20/26	Date Complete 4/20/26
Branch - Customer No. 1-42343	Home 336 407-0589	Work	Time Started 9:45	Time Completed 3:00
Name GEORGE ISLER	Address 4517 LACOSTA DR	City ALBANY, GA	State	Zip 31721-9483
Service Address 4517 LACOSTA LANE	ALBANY, GA	31721	GILLIONVILLE RD LFT ON 8 MI RD LFT INTO STONEBRIDGE	

Work to be performed: DELIVER AND INSTALL RINNAI RX180iN WITH RIKF INSTALL KIT, 184162PP ROOF DISCHARGE, 189958 FLASHING, AND 11470 CAMCO DRAIN PAN. CALLED IN BY MR. ISLER. 336-407-0589 CELL:

Work completed: *Delivered and installed Rinnai*

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	W-R 11470	39.00	39.00	1	W-R RX180iN/PP	1428.00	1428.00
1	CAMCO Drain Pan			1	Rinnai		
1	45° pp vent EC 224072PP	41.-	41.-	1	W-R RIKF	98.00	98.00
1	224080PP 39" vent	45.-	45.-		Install kit		
1	224079PP 19.5 vent			1	W-R 184162PP	84.00	84.00
1	224078PP 10" vent				Roof termination		
				1	W-R 189958	92.00	92.00
					Flashing		

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 125	Serial 64429	Tank Percent 70%
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

Manometer Reading at Start	Manometer Reading After 10 minutes	Flow Check Manometer Reading Under Load	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
8	8	11.5	12	MATERIAL TOTAL	1823.50
Central Heating	Water Heater	Range	Clothes Dryer	TRIP CHARGE	
Manufacturer Rinnai	Model No. RX180i	Serial No. TG.BA-151859	Sed. Trap Vent	LABOR	
Fuel/BTU 000	180 000	N/A	N/A	SUB-LABOR <i>Rebak</i>	<200.00
AGE New	Shut off Installed yes			PERMIT	
				SHIPPING/FREIGHT	

<input type="checkbox"/> CASH	<input type="checkbox"/> CHECK	RECEIVED BY	Date	Thank You	SALES TAX	145.88
Work Completed by: <i>Curtis Royle</i>	Date: <i>4/20/26</i>	Customer Signature: <i>George Isler</i>	Date: <i>4/20/26</i>	TOTAL	1769.38	
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY				ANY UNUSED GAS PIPING OUTLETS INDOORS?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
				IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
				CUSTOMER AVAILABLE	<input type="checkbox"/> YES <input type="checkbox"/> NO	
				CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE	<input type="checkbox"/> YES <input type="checkbox"/> NO	