

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: TREY HUDSON
353 FRANK CHURCH RD
OCILLA, GA 31774

INVOICE NO: 57225
DATE: 4/13/26

CUSTOMER NO: 3095/3178

TYPE: RO - RESIDENTIAL COUNTY BenHil

QUANTITY

DESCRIPTION

UNIT PRICE

EXTENDED PRICE

1.00	MDSE - Appliances SERIAL# WB.UA-012322 Inventory item selected for charge code: AP-60000163021 Quantity: 1.00 351-RE199EP	1,414.97	1,414.97
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	187.13	187.13
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	69.60	69.60
1.00	Sales Tax	133.74	133.74

TOTAL DUE: \$1,805.44

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 4/13/26 DUE DATE: 4/23/26
CUSTOMER NO: 3095/3178

NAME: HUDSON, TREY
TYPE: RO - RESIDENTIAL COUNTY BenHil

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD
GA 31750

INVOICE NO: 57225
TERMS: NET 10 DAYS

AMOUNT:

GA Rebate \$1,805.44
- 200.00
1605.44

Account Number 3095
 Name Troy Hudson
 Address 353 Frank Church Rd
Osilla

Call Date: 4/13/26 Date Requested: 4/13/26
 Instructions: mount tankless WH & run line

Telephone Office: _____ Home: _____

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6	7
Manufacturer			Rinnai				
Model No.			RE199e				
Serial No.			WB. UA-012322				
Location			Exterior				
BTU	000	000	199 000	N/A	N/A	000	000
Age			New				
Manual Shutoff (Installed/Existing)			installed				
Venting			gd				

TANK/CYLINDER Existing

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test
											Cond.	Date	Cap	

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
TWO STAGE 1ST	Copper	1/2	03/22	Used	Ryo	LV404BY	Level	Done	11 IN. WC
TWO STAGE 2ND									PSIG

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.)	(Inches W.C.)		
TWO STAGE 1ST	11 (PSIG)	11 (PSIG)	5min	✓OK
TWO STAGE 2ND	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.)	(Inches W.C.)		

Comments: _____

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. WF0559708 Date 4/13/26
 (Mo. Day/Yr.)

I, Troy Hudson (Please Print)

I, Chris Woods (Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

Certify that I have completed the System Check as prescribed

Performed Odor Test Yes Performed Pressure Test Yes
 Left Consumer Safety Info Yes

Troy Hudson
 Customer's Signature

Chris Woods
 Delivery Man / Technician Signature