



congerlpgas.com

INVOICE / WORK ORDER NO.

127436

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Aubrey Thompson RT# _____ RT. SEQ. _____ ACCT # 1-50695 DATE 2/12/26 INT Ln

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 126 Cedar Ridge Rd. APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31794

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

email: thompson-ac@hotmail.com

cell # 229-382-6458

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Relcoep Rinnai	TGUA-078160			1099.95
1	Service Valve Kit	MIVK-T-2W			

WORK PERFORMED: <u>Gas Check</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	1099.95
	MAKE: <u>Fisher</u>	MODEL: <u>High</u>	PARTS/MAT. USED		
	DATE CODE: <u>02-2000</u>	VENT: <u>Down</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX _____ %	8500
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH:	1st Stage	2nd Stage	LOW	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP:	11 PSI	PSI	START LOCK-UP:	W.C. LABOR
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	5 PSI	PSI	TANK OFF: PRESSURE	W.C.
		AFTER 10 MINUTES:	5 PSI	PSI	AFTER 10 MINUTES:	W.C.
		PRESSURE AS LEFT:	11 PSI	PSI	PRESSURE AS LEFT:	W.C.
X		PIPING PRESSURE TEST			INV. TOTAL	GR 200.00
CUSTOMER SIGNATURE		START	PSIG	FINISH	PSIG	AMOUNT RECEIVED
						987.95

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

5/7/26
DATE

X

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY