



INVOICE

№ 11354

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Luke Anderson</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>1678 Woodcrest Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Douglas GA 31533</u>	TE PROMISED	_____
PHONE	<u>912-592-2503</u>	DATE COMPLETED	<u>4-21-26</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS install 500 gallon AG/LG tank, run gas lines, install two tankless water heaters, griddle, range, & gas logs

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	500 gallon AG/LG Quality Steel propane tank		3800 00
1	17 Lb. Anode bag		300 00
400	gallon of propane	2.99	1196 00
1	Rinnai RE180EP tankless water heater, ser # TH.11A-116500		1285 00
1	Rinnai RE199EP tankless water heater, ser # TF.11A-087279		1500 00
2	Rinnai RGBRE recess box	319 00	638 00
1	30" Peterson G10-24/30-15(M)P gas Log w/vh remote		1398 50
130'	1/2" Counterstrike Trac Pipe CSST	5 09	661 70
80'	3/4" Counterstrike Trac Pipe CSST	6 59	527 20
1	Mini excavator rental		300 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>installed 500 gallon AG/LG tank, two tankless water heaters, griddle, range, gas logs, & all gas lines, converted range to LP, ran pressure check, lit & checked out appliances</u>	TOTAL MATERIAL	11,606 40
	TOTAL TIME _____ HOURS	LABOR	3250 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>Daniel Sikes</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	928 51
		TOTAL DUE	15,784 91

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>500</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1546810</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>400 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPA rebate 400.00 AMOUNT
\$ 15,384.91

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 4/24/26
 Name Luke Anderson Company Sikes Propane, Inc.
 Address 1678 Woodcrest Rd. Call Taken By _____
 City Douglas State GA Zip 31533 Telephone (Cell) 912-592-2503 (Home) _____

Appliance Check

Appliance	water heater	water heater	gas Logs	Range	Griddle	Generator
Manufacturer	Rinnai	Rinnai	Peterson	Kitchen Aid	Blaze	Generac
Model #	RE180ep	RE199ep	G10-24/30 -15C.M.P	KFDC506 J6504	BLZ-GRID DLE 40-LP	G0072900
Serial #	TH.UA-116 500	TF.UA-08 7279	2105466	DE1302301	3WOP-1483 24D015	30181068 05
BTU's	180,000	199,000	37,000	64,000	45,000	330,000
Burner - Cons. Chamber	ok	ok	ok	ok	ok	ok
Man. Shutoff - Sed. Trap	installed	installed	installed	installed	installed	installed
Control - Pilot Safety System	ok	ok	ok	ok	ok	ok
Venting System	ok	ok	ok	ok	ok	ok
Age	new	new	new	new	new	new
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
500	1546810	Quality Steel	2025	ok	new	02C23	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
110psi	110psi	10min.	0
			Work Order 0

Piping Check

Materials	Size	Cover / Protection
Trac Pipe	3/4" x 1/2"	ok
Coated copper	1/2" x 3/8"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9in.wc.	9in.wc.	10min.	0
			Work Order 0

Regulator Check

Type	Manufacturer	Date / Model	Vent Position/ Protection
First	Rego	05E2025 / LV4403TR9	u-c
Second	Rego	01C2025 / LV4403Y4	down
Second	Rego	10D2025 / LV4403B66R	down
Second	Maxitrol	325-5L (x2), 325-3L (x2)	horizontal

Safety Information Supplied: _____

Comments: Please note all repairs and corrections made along with any recommended actions.