



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID ROBAND
Account # 592
Invoice # S0014481
Invoice Date 5/1/2026

Sold To

ANDY/ROBIN ROBINSON
1289 ROBERTA HWY
BUTLER, GA 31006-3749

Shipped To Location 1
ANDY/ROBIN ROBINSON
1289 ROBERTA HWY
BUTLER, GA 31006-3749

Date 5/1/2026

Terms due upon receipt

Salesperson 6

Order Date

PO #

Ship Via

Quantity	Category	Description	Unit Price	Amount
1.00	RE180EP	Rinnai Water Heater	1,385.0000	\$1,385.00
		REGULAR SALES TAXABLE		110.80
1.00	MIVK-T-LW	Plumbing kit for rinnai	150.0000	\$150.00
		REGULAR SALES TAXABLE		12.00
1.00	491002	3/4 Cutoff	15.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
1.00	45226	3/4 X Close Black Nipple	2.5000	\$2.50
		REGULAR SALES TAXABLE		0.22
1.00	45051	3/4" Black Tee	6.0000	\$6.00
		REGULAR SALES TAXABLE		0.48
1.00	49-8-12	1/2"X3/4" FIXMale Elbow	4.5000	\$4.50
		REGULAR SALES TAXABLE		0.38
2.00	40-8	1/2" Flare Nut	2.5000	\$5.00
		REGULAR SALES TAXABLE		0.40
50.00	12R50	1/2" COPPER TUBING	4.0000	\$200.00
		REGULAR SALES TAXABLE		16.00
8.00	58R50	5/8" Copper Tubing	5.5000	\$44.00
		REGULAR SALES TAXABLE		3.52
2.00	40-10	5/8" Flare Nut	3.2500	\$6.50
		REGULAR SALES TAXABLE		0.54
2.00	XR10B8S	1/2"x1/2" Poly Riser 36"	50.0000	\$100.00
	N36LZ			
		REGULAR SALES TAXABLE		8.00
32.00	PP12CTS	1/2 POLY PIPE	0.5000	\$16.00
		REGULAR SALES TAXABLE		1.28
32.00	1430Y	TRACER WIRE	0.3000	\$9.60
		REGULAR SALES TAXABLE		0.78
1.00	48-10-12	5/8X3/4 FI X Male Conn	4.2500	\$4.25
		REGULAR SALES TAXABLE		0.33
1.00		PERF REBATE	-200.0000	(\$200.00)
1.00		LABOR	150.0000	\$150.00



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID ROBAND
Account # 592
Invoice # S0014481
Invoice Date 5/1/2026

Sold To
ANDY/ROBIN ROBINSON
1289 ROBERTA HWY
BUTLER, GA 31006-3749

Shipped To Location 1
ANDY/ROBIN ROBINSON
1289 ROBERTA HWY
BUTLER, GA 31006-3749

Date 5/1/2026
Salesperson 6
PO #

Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
----------	----------	-------------	------------	--------

Subtotal	\$1,898.35
GA TAYLOR CO TAX	\$155.93
HEADER	
Invoice Total	\$2,054.28

Total Due	\$2,054.28
-----------	------------



PROPANE SAFETY INSPECTION



Account # 592 Name ANDY/ROBIN ROBINSON Address [1] 1289 ROBERTA HWY City BUTLER
State GA Zip 31006-3749 Phone 0 Date of Inspection 04/30/2026 Branch/Location Work Order #

Equipment Type	Water Heater	Range	Log Set		
Manufacturer	Rinnai	General Electric (GE)	HearthRite		
Year Manufactured					
Model #	ra180ep	ggf600av2ss	Lum-vf-pv		
Serial #	wc. ua-030398	ra046043q	0001304		
Fuel	Propane	Propane	Propane		
BTUs (Maximum Input)	180,000	65,000	30,000		
Manual Shutoff Valve	OK	OK	OK		
Sediment Trap		N/A	N/A		
Burner(s) Condition	OK	OK	OK		
Combustion Chamber Condition	OK	N/A	N/A		
Control/Pilot Safety System	OK Electronic	OK Electronic	OK Pilot		
Venting System	N/A or No	N/A or No	N/A or No		
Combustion Air	Service Not Provided	Service Not Provided	Service Not Provided		
Taken Out of Svc or Operation (Tag #)	No	No	No		

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/ DOT	AG/UG/AGUG					Last Regual Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	2sg 064174		ASME	AG	250 wg		American Welding	2003	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING		Material	Size	Protection	REGULATORS		Mfr.	Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	PE (Plastic)	1/2	OK		1st Stg	REGO	Iv4404tr9	2003	OK	OK	OK
	2nd Stg	CT (Copper Tubing)	5/8	OK		2nd Stg	REGO	Iv4404b9	2003	OK	OK	OK
	2nd Stg	CT (Copper Tubing)	1/2	OK								

CSST TRACKING	Bonded	☐ Yes ☐ No ☐ Unknown	Jurisdictional Acct.	☐ Y ☒ N ☐ Unknown	Gas Lines Capped	☐ Y ☒ N/A	Heat Pump	☐ Y ☒ N
---------------	--------	---	----------------------	---	------------------	--	-----------	--

System Type	System Leak Check ☒ Entire System					Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time		Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
1st Stage	12 / 7 ☒ WC ☐ PSI	7 ☒ WC ☐ PSI	10:30	10:35		10 PSI	10 PSI	10:20	10:30	11 ☒ WC ☐ PSI	12 ☒ WC ☐ PSI		
	☒ WC ☐ PSI	☒ WC ☐ PSI				PSI	PSI			☒ WC ☐ PSI	☒ WC ☐ PSI		
	☒ WC ☐ PSI	☒ WC ☐ PSI				PSI	PSI			☒ WC ☐ PSI	☒ WC ☐ PSI		
	☒ WC ☐ PSI	☒ WC ☐ PSI				PSI	PSI			☒ WC ☐ PSI	☒ WC ☐ PSI		

Performed Sniff Test	☒ Y ☐ N	Comments	moved tank, ran lines, installed tankless water heater. leak tested. ;
----------------------	--	----------	--

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☒ Property Owner ☐ Tenant ☐ Authorized Representative, acknowledge that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. I further acknowledge that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
 - I am satisfied with the service work performed.
 - I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.
- I have been provided the following additional safety materials:
- ☒ Propane Safety Booklet (PRC-005606 or PRC-101063)
 - ☒ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
 - ☒ Carbon Monoxide Brochure (PRC-000075)

Brandon Rustin
Service Technician Name - Print

Service Technician Signature

04/30/2026
Date

ANDY/ROBIN ROBINSON
Customer Name - Print

Customer Signature

04/30/2026
Date