

SALES
SERVICE
INSTALLATION



RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 894630	Date Written 4/13/26	Taken By MEH	Schedule Date 4/20/26	Date Completed 4-20-2026
Branch - Customer No. 1-55321	Home 910-546-2377	Work	Time Started 9:00	Time Completed 2:00
Name JENNIFER MABEE	Address 115 GLEN ARVEN DR	City LEESBURG, GA	State GA	Zip 31763-5366
Service Address 115 GLEN ARVEN DR LEESBURG, GA 31763			DAWSON RD LFT HICKORY GRV LFT WHITE COLUMN DR RT GLEN ARVEN HSE ON LFT	

Work to be performed:	Work completed
DELIVER AND INSTALL RINNAI RX160iN WITH RIKF INSTALL KIT, 184162PP CONDENSING ROOF DISCHARGE, 189951 FLASHING, 11470 CAMCO DRAIN PAN AND OTHER VENTING. CALLED IN BY JENNIFER. 910-546-2397 CELL: Up	Delivered installed and vented Rinnai

Qty	Materials	Price	Amount	Qty	Materials	Price	Amount
1	W-R 11470 CAMCO Drain Pan	39.00		1	W-R RX160IN Rinnai	1088.00	
1	224080PP 39" vent	45.-		1	W-R R7kF Install kit	98.00	
1	224077PP 45° EL	41.-		1	W-R 184162PP Roof Discharge	84.00	
1	224079PP 19.5 vent	35.-		1	W-R 189958 Flashing	12.00	
1	224087PP 10" vent	27.-					

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size	Serial No.	Tank Percent
	61	13517	100%
Single Stage	Regular Date	Reg. Condition	Mfr.
TWO 1st	15 Dec 25	new	R122H
STAGE 2nd		Good	1225

Manometer Reading at Start	Manometer Reading After 10 minutes	Flow Check	Manometer Reading Under Load	Lock-up Check	Manometer Reading
8	8	11.5	11.5	12.5	12.5
Central Heating	Water Heater	Range	Clothes Dryer		
Manufacturer	Rinnai				
Model No.	RX160iN				
Serial No.	TG. RA155938				
Sed. Trap					
Fuel/BTU	000 160 000	N/A	N/A	000	
AGE	25				
Shut off Installed					

☐ CASH ☐ CHECK	RECEIVED BY	Date	SHOP OR TRUCK SUPPLIES MATERIAL TOTAL TRIP CHARGE LABOR SUB-LABOR Rebate PERMIT SHIPPING/FREIGHT
Work Completed by: Curtis Rouse		4-20-2026	Thank You SALES TAX TOTAL
Customer Signature: Jennifer Mabee		4-20-26	ANY UNUSED GAS PIPING OUTLETS INDOORS? IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? CUSTOMER AVAILABLE CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY			YES NO YES NO YES NO YES NO