

R

25 / m. 100

Order Number 896478		Date Written 5/15/26		Taken By: JC		Schedule Date 5/18/26		Date Completed 5/18/26							
Branch - Customer No. 1-87193		Home 229 322-1399		Work Cell		Time Started 1:10		Time Completed 2:35							
Name DEBBIE WATERS		Address 562 N SPRING CREEK CIRCLE		City COBB, GA		State 31735-2017		Zip							
Service Address 562 N SPRING CREEK CCOBB, GA 31735															
Work to be performed: DEL & INSTAL RINNAI RX180IN/P W/ RIKF KIT, RXOVC COVER, MC-601 CONTROLLER & PCD11-SHS PIPE COVER; PER MS WATERS; CALL 229-322-1399 WHEN ON THE WAY						Work completed Removed old water heater Installed New water heater									
Qty:		Materials		Price		Amount		Qty:		Materials		Price		Amount	
2		3/4 Shark bite coupling				57.02		1		WR RX180IN				1,428.-	
3		3/4 MIP Pex Adapter				12.21		1		TL BA-260953					
3		3/4 Pex Rings				1.26		1		WR RIKF				98.-	
2		3/4 Pex Pipe				2.-		1		WR RXOVC				51.-	
						T= 72.49		1		WR MC 601				148.-	
								1		WR PCD11SHS				183.-	
DR. RT.		Rt. Seq.		Rate		Deposit									
Tank Make		Size 120		Serial A5900		Tank Percent									
Single Stage		Regular Date		Reg. Condition		Mfr.		Model		Vent Pos.		Protected?			
TWO 1st															
STAGE 2nd															
Less Check		Flow Check		Lock-up Check		SHOP OR TRUCK SUPPLIES		16 50							
Manometer Reading at Start 9.3		Manometer Reading After 10 minutes 9.3		Manometer Reading Under Load		Manometer Reading		MATERIAL TOTAL 1996 99							
Central Heating		Water Heater		Range		Clothes Dryer		TRIP CHARGE							
Manufacturer Rinnai		Model No. RX180IN/P		Serial No. TL BA260953		Sed. Trap Vent		LABOR 195 -							
Fuel/BTU 000 180 000		N/A		N/A		000		SUB-LABOR Rebate < 200 00							
AGE 25		4						PERMIT							
Shut off Installed								SHIPPING/FREIGHT							
CASH		RECEIVED BY		Date 5/18/26		Thank You		SALES TAX 159 76							
CHECK				Date 5/18/26		TOTAL 2151 75		CUSTOMER AVAILABLE							
Work Completed by: [Signature]						ANY UNUSED GAS PIPING OUTLETS INDOORS?		YES NO							
Customer Signature						IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?		YES NO							
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY						CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE		YES NO							