

JB

C

4/23/2026 8:56:29 AM

WORK ORDER

Nancy Anderson

2135 Salem Church Road
Jasper, GA 30143
(770) 894-9281

Customer #: 205890
Order #: 497527
Location #: 281992
Zone: B-032-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 5/1/26 Final H/U to house gas logs W/H and stove Call
770-656-0403 CCOF-CLT

Date Ordered: 4/23/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 3/23/2026		Last Tune Up:	
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205890

Name: NANCY ANDERSON

Address: 2135 SALEM CHURCH ROAD

JASPER GA 30143

Date: 5/1/26

Instructions: FINAL H/U TO HOUSE LOGS W/H & STOVE
CCOF-CLT

Order #: 497527

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	stove	water heater		log set		
Manufacturer	Frigidaire	Northern		hearth & home		
Model #	GCFG30608FE	NPEJ40A2		LUM-VF-PV		
Serial #	VF60849703	2087C2580464E95		MP625049164		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2602028	Good	Triarc	2026	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	04/2025	☒ Correct ☐ Incorrect		
2nd	MEC	16 FEB 23	☒ Correct ☐ Incorrect	11.7	12.4

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Pressure Test:

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Brandon Payne	Service Technician (Signature) Brandon Payne	Date 5-1-18
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: **205890**
Name **NANCY ANDERSON**
Address **2136 SALEM CHURCH RD**
JASPER GA 30143

Date: **3-23-26**
Instructions: **DROP 250UG W/50G @ 2.499 CCOF JB**
770-894-9281
Order #: **486097**

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to **3** year contract for discount

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$
Standard Vent Kit \$
Standard Install \$
Total \$

\$
\$
\$
\$

Tank Set

New Cust Special

L P Gas /Gal **2.999**

L P Gas /Gal **2.499**

Gallons **50**

Gallons **50**

FRCC

\$9.79

FRCC

\$9.79

9.79

Fuel Total

149.95

Fuel Total

124.95

124.95

Tank Lease/YR **129.00**

1st yr Lease **FREE**

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee

\$250

Tank Set Fee **20.00**

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

474.57

Safe Appliance Rebate 250.00

TOTAL BALANCE DUE