

JCLT

✓

5/5/2026 1:01:21 PM

WORK ORDER

Jeff Watkins

340 S. Old Aska
Blue Ridge, GA 30513
(706) 889-3764

Customer #: 205397
Order #: 503598
Location #: 281395
Zone: B-010-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service 5/12/24

Description: ~~5/7~~ - Run gas lint from tank to generator and to the house. Chg.
Call Jeff 706-889-3764

Date Ordered: 5/5/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 1/19/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205397

Date: 5-12-26

Name: JEFF WATKINS

Instructions: RUN LINE TO GENERATOR AND HOUSE

Address: 340 S OLD ASKA
BLUE RIDGE GA 30513

CHARGE 706-889-3764

Order #: 503598

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Generator		Furnace			
Manufacturer	General		Rheem			
Model #	600704311		R92110855A21M45N95			
Serial #	3017310042		W512517447			
Burner/Combustion Chamber	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2519570	300d	TriArc	2025	46	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC	ME6R-122H 25 Mar 24	☒ Correct ☐ Incorrect		
2nd	Re30	4403B46 2025	☒ Correct ☐ Incorrect	11.2	12.9

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
105 PSI	105 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Dillon Payne	Service Technician (Signature) Dillon Payne	Date 5/12/26
Customer (Print)	Customer (Signature)	Date

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: **205397**

Name **JEFF WATKINS**

Address **340 S OLD AKSA**

BLUE RIDGE GA 30513

Date: **1-19-26**

Instructions: **DROP 500UG W/50G @ 2.599 1 ANODE BAC**

Order #: **452707**

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$	
Standard Vent Kit \$	\$	
Standard Install \$	\$	
Total \$	\$	

Tank Set

New Cust Special

L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.599	
Gallons 50	Gallons 50	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 599.80	Fuel Total 519.80	519.80
Tank Lease/YR 129.00	1st yr Lease FREE	FREE

Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings **521.53**
Safe Appliance Rebate 400.00

TOTAL BALANCE DUE