

Unable to leave
a msg. JB

5/6/2026 6:56:47 AM

WORK ORDER

Marc Nicholson

919 Price Rd Lot #15
Blue Ridge, GA 30513
(706) 455-1078

Customer #: 204913
Order #: 503702
Location #: 280791
Zone: B-005-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 05/14/26 - FINAL HOOK, RUN YD LINE, HOOK UP W/HEATER,
HVAC, STOVE KIT ON SITE, GAS LOGS., OUTSIDE
FIRETABLE - CALL 706-455-1078 - EMAIL INVOICE - CT

601st

Date Ordered: 5/6/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service: 2/6/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204913

Date: 5-14-26

Go 1st

Name: MARC NICHOLSON

Address: 919 PRICE RD LOT # 15

BLUE RIDGE GA 30513

Instructions: RFINAL HOOK UP RUN RD LINEHOOK UP W/H

HVAC CONNVERT AND CONNECT STOVE GAS LOGS AND

OUTSIDE FIRETABLE 706-455-1078 CT

Order #: 503702

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	furnace		W/H			
Manufacturer	temt+stal		Rinnig			
Model #	P92MSN0801716A1		-RX1601			
Serial #	A252065012		T2BA-211586			
Burner/Combustion Chamber	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2527201	900d	triarc	2025	46	900d

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rejo	3403TR9	☒ Correct ☐ Incorrect		
2nd	Rejo	440334	☒ Correct ☐ Incorrect	11.1	12.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
25 PSI	75 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Dillon Payne	Service Technician (Signature)	Dillon Payne	Date	5/14/26
Customer (Print)		Customer (Signature)		Date	

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 204913
Name MARC NICHOLSON
Address 919 PRICE RD LOT #15
BLUE RIDGE, GA 30513

Date: 11/19/25
Instructions: DROP 500UG W/50G@2.599G DROP ANODE BA
CALL 706-455-1078 EMAIL INVOICE
Order #: 420986

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.599
Gallons	50	Gallons 50
FRCC	\$9.79	FRCC \$9.79 9.79
Fuel Total	149.95	Fuel Total 129.95 129.95
Tank Lease/YR	129.00	1st yr Lease FREE FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250		Tank Set Fee 20.00 20.00
Safety Inspection \$129.95		\$29.95 29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		487.33
Safe Appliance Rebate		600.00
TOTAL BALANCE DUE		