

5/15/2026 9:31:40 AM

WORK ORDER

Frank Smith

140 Settlers Ridge Drive
Ballground, GA 30107
(404) 401-6066

Customer #: 206017
Order #: 505495
Location #: 282170
Zone:
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 5/15/26 C/C stove on site CCOF Call -CLT

Date Ordered: 5/15/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service: 5/11/2026

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206017Date: 5-15-26Name: Frank Smith

Instructions: _____

Address: 140 Settlers Ridge Dr. Ballground
GA 30107Order #: 505495

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	GE					
Model #	PGS930YP9FS					
Serial #	6D483437P					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2504347	Good	Thiarc	2025	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC	1622H	20 Jul 22	☐ Correct ☐ Incorrect	
2nd	Rego	LV340364	10/2025	☒ Correct ☐ Incorrect	11.9
					12.6

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments: _____

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) <u>Branan Payne</u>	Service Technician (Signature) <u>Branan Payne</u>	Date <u>5-15-26</u>
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206017

Name **FRANK SMITH**

Address **140 SETTLERS RIDGE DRIVE**

BALLGROUND GA 30107

Date: 5/1/26

Instructions: **DROP 250UG W/50G@2.499 ANODE BAG
GC TO BURY CCOF-CLT**

Order #497945

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L P Gas /Gal 2.999

L P Gas /Gal 2.499

Gallons 50

Gallons 50

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 149.95

Fuel Total 124.95

124.95

Tank Lease/YR 129.00

1st yr Lease FREE

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee 20.00

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

474.57

Safe Appliance Rebate

50.00

TOTAL BALANCE DUE