

5/15/2026 8:58:15 AM

WORK ORDER

Rodney Jones

200 Jasmine Court
Ellijay, GA 30540
(813) 892-9161

Customer #: 206083
Order #: 505474
Location #: 282258
Zone:
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 05/18/26 - T/I 120AG W/100G @3.599 + C/C STOVE IF
ONSITE. Hook to grill onsite. Lines should be ran. Call:
813-892-9161 CCOF - JB
CALL BEFORE RUNNING CARD FOR SERVICE

Date Ordered: 5/15/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service:

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206083

Date: 5/18/26

Name: RODNEY JONES

Instructions: T/I 120AG W/100G@3.599+C/C STOVE

Address: 200 JASMINE COURT

IF ONSITE.H/U GRILL. LINES THERE. 813-892-9161

ELLIJAY, GA 30540

Order #: 505474

CCOF - JB

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	LG					
Model #	LS6L6337K/00					
Serial #	503KMEMIV748					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
120	M1242400	Good	Trinity	2012	AG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin	~~Rego~~		☐ Correct ☐ Incorrect		
1st	Rego	3303TR	☒ Correct ☐ Incorrect		
2nd	Rego	3304B4	☒ Correct ☐ Incorrect	11.3	13.4

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Brandon Payne	Service Technician (Signature)	Brandon Payne	Date	5/18/26
Customer (Print)	R. Rodney Jones	Customer (Signature)	R. Rodney Jones	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206083
Name RODNEY JONES
Address 200 JASMINE COURT
ELLIJAY, GA 30540

Date: 5/18/26

Instructions: T/I 120AG W/100G@3.599C/C STOVE IF
ONSITE. LINES SHOULD BE THERE. H/U GRILL. CCOF - JB

Order #: 505474 CALL: 813-892-9161

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

<u> </u> Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	3.599	L.P. Gas /Gal	3.599
Gallons	100	Gallons	100
FRCC	\$9.79	FRCC	\$9.79 9.79
Fuel Total	359.90	Fuel Total	359.90 359.90
Tank Lease/YR	99.00	1st yr Lease	99.00 99.00

Total Materials	
Sub-Total	
Sales Tax	
Tank Set Fee \$250	Tank Set Fee FREE FREE
Safety Inspection \$129.95	\$29.95 29.95
Total Labor	
Total charges	
Prepay Bal On Account	

Safe Appliance Savings **350.00**

Safe Appliance Rebate **50.00**

TOTAL BALANCE DUE