

vclt

5/18/2026 1:18:22 PM

WORK ORDER

Anthony Falls

66 Woodland Trail
Epworth, GA 30541
(706) 455-1216

T/I 48" Linear glass 5boxes
T/I 30" Carol Rose outdoor SS
w/ Wildwood Refractory

Customer #: 205658
Order #: 505943
Location #: 281696
Zone: B-005-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service 260

Description: 05/22/26 - 325AG W/26G @2.499 + RUN YARD LINE, H/U FURNACE, H/U FP MAIN LEVEL, H/U OUTDOOR FP, ONSITE.
T/I glass for linear. CALL: 706-455-1216 invoice - JB

Date Ordered: 5/18/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:	Last Service: 2/12/2026	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: **205658**

Date: **5/22/26**

Name: **ANTHONY FALLS**

Instructions: **325AGW/260G@2.499+RUN YRD LINE.H/U FUR**

Address: **66 WOODLAND TRAIL**

MAIN LEVEL FP, OUTDOOR FP ONSITE. T/I GLASS LIN

CALL: **706-455-1216 INVOICE-JB**

Order #: **505943**

EPWORTH, GA 30541

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Female	Linear	Loose			
Manufacturer	Carrier	Empire	Empire			
Model #	R92MSN0801716A1	6FLB47FP90R4	0NR30P-2			
Serial #	A253064993	2531P431155	2444P392290			
Burner/Combustion Chamber	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	25H016434	Good	American	1994	AC	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Roso	34037729	2-26	☒ Correct ☐ Incorrect	
2nd	Roso	3403734	10-23	☒ Correct ☐ Incorrect	11.6
					13.7

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
130 PSI	130 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Alvin Winters	Service Technician (Signature)	[Signature]	Date	5-22-26
Customer (Print)	Customer not present	Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 205658
Name ANTHONY FALLS
Address 66 WOODLAND TRAIL
EPWORTH, GA 30541

Date: 5/22/26
Instructions: T/I 325AG W/260G@2.499+ RUN YARD LINE
H/U FURNACE, MAIN LEVEL FP, OUTDOOR FP ONSITE.
Order #: 505943 CALL: 706-455-1216 INVOICE - JB

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes No
Gas check attached	Yes No
Leak check	Initial
Start Pressure	End Pressure Time Held System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to year contract for discount.
CUSTOMER SIGNATURE

Retail Price	Contract Price
Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$
Tank Set	New Cust Special
L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499
Gallons 260	Gallons 260
FRCC \$9.79	FRCC \$9.79
Fuel Total 779.74	Fuel Total 649.74
Tank Lease/YR 99.00	1st yr Lease FREE
Total Materials	
Sub-Total	
Sales Tax	
Tank Set Fee \$250	Tank Set Fee 20.00
Safety Inspection \$129.95	\$29.95
Total Labor	
Total charges	
Prepay Bal On Account	
Safe Appliance Savings	575.03
Safe Appliance Rebate	400.00
TOTAL BALANCE DUE	