

WORK ORDER

David Underwood

1814 Mountain Creek Drive
Pendergrass, GA 30567
(706) 654-7104

Customer # : 206046
Order # : 503799
Location # : 282208
Zone: J-021-MED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 5-12-26, ccof, S/O with tank on site w/ moved tank from hubert
pittman rd pump over 20% and h/u, call Mrs. Murphy on the way
706-654-7104

Date Ordered: 5/6/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service:

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
-------------	------------------	-------------	-------------------------	----------------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206046

Date: 5/12/26

Name: DAVID UNDERWOOD

Instructions: SET C/O TANK MOVED FROM HUBERT

Address: 1814 MOUNTAIN CREEK CHURCH DRIVE

PITTMAN RD PUMP OVER 20%

PENDERGRASS, GA 30567

Order #:

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Cooltop	Furnace				
Manufacturer	major brand	IRANE				
Model #	6257XLS	DHBA0506DSD				
Serial #	15759768MK	WJG6744232				
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☒ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	25V011533	Good	American	1997	A/G	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin	Rejo	LVH0439	☒ Correct ☐ Incorrect	10.5	17.5
1st			☐ Correct ☐ Incorrect		
2nd			☐ Correct ☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
80 PSI	80 PSI	15 Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments:

30' in tank / All appliances in working condition

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Owen Dins	Owen Dins	5/12/26
Customer (Print)	Customer (Signature)	Date
	Jan Murphy	