



INVOICE

No 11381

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	Angelisa Hodges	ACCOUNT NO.	
MAIL ADDRESS	469 Palmetto Ln.	DATE ORDERED	
CITY/STATE/ZIP	Baxley GA 31513	DATE PROMISED	
PHONE	912-318-9495	DATE COMPLETED	5-13-26
LOCATION		TERMS	

INSTRUCTIONS set 250 gallon tank, run gas line to house, install all gas appliances

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
200	gallon of propane	2 99	598 00
55'	1/2" coated copper tubing	3 99	219 45
1	3/8" cut off valve		12 95
2	1/2" flare nut	1 60	3 20
7	3/8" flare nut	1 50	10 50

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	SERVICES PERFORMED <u>set 250 gallon tank, run gas line to house, installed all gas appliances, converted dryer & cook top to LP, ran pressure check, lit & checked out appliances</u>	TOTAL MATERIAL	844 10
	TOTAL TIME _____ HOURS	LABOR	650 00
THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>Daniel Sikes</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	67 53
		TOTAL DUE	1561 63

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: 250	SIZE	START LOCK UP:	START JACK UP:
S/N: 1554031	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: 200 gal	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPGA rebate 300.00
AMOUNT
\$ 1261.63

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 5/13/26
 Name Angelisa Hodges Company Sikes Propane, Inc.
 Address 469 Palmetto Ln. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-318-9495 (Home) _____

Appliance Check

Appliance	water heater	Gas Logs		cooktop	Gas Dryer
Manufacturer	Rinnai	Peterson		Frigidaire	Alliance Speed Queen
Model #	RE180e	G10-24/30-15CM)P		GCCG304	ADG4BR65
Serial #	THUA-116495	2082241		1F44890159	112TW01
BTU's	180,000	37,000		48,000	22,500
Burner / Com. Chamber	ok	ok		ok	ok
Man. Shutoff / Sed. Trap	installed	installed		installed	installed
Control / Pilot Safety System	ok	ok		ok	ok
Venting System	ok	ok		ok	ok
Age	new	new		new	new
Taken Out Of Service Or Operation					

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	1554031	Quality Steel	2025	ok	new	02C23	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
115psi.	115psi.	10min.	0
			N
			Work Order
			0
			N

Piping Check

Materials	Size	Cover / Protection
Trac pipe	1/2"	ok
coated copper	1/2" + 3/8"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9in. wc.	9in. wc.	10min.	0
			N
			Work Order
			0
			N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
First	Rego	05C2025 / LV4403TR9	u-c
Second	Rego	/LV4403Y4	down
Second	Maxitrol	325-3L	horizontal
Second	Maxitrol	325-5L	horizontal

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.