

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: OCILLA MEAT MARKET
509 E 4th ST
OCILLA, GA 31774

INVOICE NO: 57633
DATE: 6/09/26

CUSTOMER NO: 3781/3857

TYPE: CI - COMMERCIAL CITY

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SERIAL# WC UA 030248 Inventory item selected for charge code: AP-60000163021 Quantity: 1.00 351-RE199EP	1,414.97	1,414.97
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	198.72	198.72
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	75.38	75.38
1.00	Sales Tax	135.13	135.13
1.00	Tank Lease	60.00	60.00

TOTAL DUE: \$1,884.20

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 6/09/26 DUE DATE: 6/19/26
CUSTOMER NO: 3781/3857

NAME: OCILLA MEAT MARKET
TYPE: CI - COMMERCIAL CITY

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD GA 31750

INVOICE NO: 57633
TERMS: NET 10 DAYS

AMOUNT:

\$1,884.20

GA
Rebate

200.00
\$1,684.20

Account Number 3781

Name Ocilla Meat Market

Address 509 E. 4th St.

Ocilla, GA

Call Date: 6/9/26

Date Requested: 6/9/26

Instructions: Set tank / mount water heater & run line

Telephone Office: _____

Home: _____

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6
Manufacturer			<u>Rinnai</u>			
Model No.			<u>RE199e</u>			
Serial No.			<u>WC, UA-030248</u>			
Location			<u>Extension</u>			
BTU	000	000	<u>199 000</u>	<u>N/A</u>	<u>N/A</u>	<u>000 000</u>
Age			<u>New</u>			
Manual Shutoff (Installed/Existing)			<u>Installed</u>			
Venting			<u>gd</u>			

TANK/CYLINDER 196 G

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings
											Cond.	Date	Cap	Leak Test
<u>120</u>	<u>1A68294</u>	<u>AW</u>	<u>1985</u>	<u>5/1/26</u>	<u>Extension</u>	<u>gd</u>	<u>gd</u>	<u>new</u>	<u>gd</u>	<u>gd</u>	<u>gd</u>	<u>-</u>	<u>gd</u>	<u>5 min</u>

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
	<u>Copper</u>	<u>1/2</u>	<u>02/25</u>	<u>New</u>	<u>Fego</u>	<u>LV40484</u>	<u>Level</u>	<u>Done</u>	<u>11 IN. WC</u>
TWO STAGE	1ST								
	2ND								<u>PSIG</u>

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure (Inches W.C.)	End Pressure (Inches W.C.)	Time Held	System OK
	<u>11</u>	<u>11</u>	<u>5 min</u>	<u>✓ OK</u>
TWO STAGE	1ST			
	2ND			

Comments: _____

Reference Invoice No. WFO564022 Date 6/9/26
(Mo. Day Yr.)

Chris Woods
(Please Print)

Certify that I have completed the System Check as prescribed

Performed Odor Test ☒ Yes

Performed Pressure Test ☒ Yes
Left Consumer Safety Info ☒ Yes

Chris Woods

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

I, Rodney Bullock
(Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and/or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

Rodney Bullock