



congerlpgas.com

Ga:

125602

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

2310-B Highway 84 W  
Valdosta, GA 31602  
(229) 469-4250

NAME Parrell Waites RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 03-24462 DATE 12/24/25 INT DB

MAILING ADDRESS 396 Pointtree Bridge Rd CITY \_\_\_\_\_

ADDRESS \_\_\_\_\_ APT/LOT NO. \_\_\_\_\_

CITY Norman Park STATE GA ZIP CODE 31771

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	_____
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED:  CASH  CHARGE DATE PROMISED \_\_\_\_\_

email: Waites.darrell@gmail.com  
cell # 229-873-5704  
**PAY BILL ONLINE @congerlpgas.com**

DIRECTIONS: \_\_\_\_\_

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	<u>500.</u>	<u>MP583</u>	<u>0%</u>						
		<u>COT,</u>							

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>GAS line parts.</u>	<u>RE180e,</u>	<u>THUA-121377,</u>		<u>1199.95</u>
					<u>35.00</u>

WORK PERFORMED: <u>FN Stalled new</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE
<u>Water Heater, no GAS</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>WH 1199.95</u>
<u>leaks.</u>	DATE CODE: <u>4-21</u>	VENT: <u>HORIZ.</u>	TANK RENT	<u>MP 35.00</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE			<u>CE 78.95</u>	
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH:	1st Stage	2nd Stage	LOW
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP:	<u>10</u> PSI	PSI	START LOCK-UP:
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE	<u>10</u> PSI	PSI	TANK OFF: PRESSURE
	AFTER 10 MINUTES:	<u>10</u> PSI	PSI	AFTER 10 MINUTES:
	PRESSURE AS LEFT:	<u>10</u> PSI	PSI	PRESSURE AS LEFT:
X _____	PIPING PRESSURE TEST			LABOR
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG
				INV. TOTAL
				<u>1348.15</u>
				AMOUNT RECEIVED
				<u>200.00</u>

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE \_\_\_\_\_ DATE 12/24/2025 CUSTOMER SIGNATURE \_\_\_\_\_