



congerlpgas.com

125783

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Alan Brightwell RT# RT. SEQ. ACCT # 03-24630 DATE 12-31-25 INT

MAILING ADDRESS CO. CITY

ADDRESS 1001 Whites rd APT/LOT NO.

CITY Mowman park STATE GA ZIP CODE 31771

NEW CUSTOMER INFORMATION S.S. NO. DELV HOME PH RENT WORK PH CREDIT LITE PILOT PC EMPLOYER DR. USE LEASE

SERVICE REQUESTED: CASH CHARGE DATE PROMISED

install 120gal tank + water heater

email: Alan.Brightwell@yahoo.com cell # 229 873 5897 PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: needs gas Releed

Table with columns: TANK PICKUP/SET, TANK SIZE, SERIAL #, TANK %, TANK DESTINATION, DOT PERMANENTLY INSTALLED CONTAINERS (MANUFACTURED DATE, LAST TEST DATE, SIZE, SERIAL #, % FULL)

Table with columns: QTY, APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED, MODEL #, SERIAL NUMBER, UNIT PRICE, SALES AMOUNT

WORK PERFORMED: Hung water heater. REGULATION INFORMATION MAKE: Rego MODEL: TR9 DATE CODE: 01D025 VENT: down

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: LEAK AND PRESSURE TEST HIGH: 1st Stage 2nd Stage LOW START LOCK-UP: 10 PSI PSI START LOCK-UP: 10 PSI PSI TANK OFF PRESSURE: 6 PSI PSI TANK OFF PRESSURE: 6 PSI PSI AFTER 10 MINUTES: 6 PSI PSI AFTER 10 MINUTES: 6 PSI PSI PRESSURE AS LEFT: 10 PSI PSI PRESSURE AS LEFT: 10 PSI PSI

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE. SERVICE REP. SIGNATURE DATE 1-6-2026 CUSTOMER SIGNATURE