



INVOICE
No. 11039

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Eugene Turner</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>302 Dixon Rd. S.E.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Surrency GA 31563</u>	DATE PROMISED	_____
PHONE	_____	DATE COMPLETED	<u>12-10-25</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS install tankless water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	<u>Rinnai RE180e tankless water heater w/isolation valves, serial # TH.UA-116501</u>		<u>1285 00</u>
1	<u>Rego LV3403B4 second stage regulator</u>		<u>59 95</u>
10'	<u>1/2" coated copper tubing</u>	<u>3 49</u>	<u>34 90</u>
1	<u>1/2" cut off valve</u>		<u>16 95</u>
4	<u>1/2" flare nut</u>	<u>1 60</u>	<u>6 40</u>
2	<u>1/2" swivel</u>	<u>3 99</u>	<u>7 98</u>
1	<u>1/2" flare tee</u>		<u>4 59</u>
2	<u>1/2" x 1/2" male adapter</u>	<u>3 09</u>	<u>6 18</u>
all	<u>other gas & water fittings, thread sealant</u>		<u>39 00</u>
		TOTAL MATERIAL	<u>1460 95</u>

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54

SERVICES PERFORMED installed tankless water heater, ran gas lines, installed regulator, ran pressure check, lit & checked out appliances

TOTAL TIME _____ HOURS

LABOR	<u>180 00</u>
SUBTOTAL	
SALES TAX	<u>116 88</u>
TOTAL DUE	<u>1757 83</u>

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X _____
CUSTOMER'S SIGNATURE

SERVICES PERFORMED BY Daniel Sikes

-GPGA rebate 202.00
AMOUNT ~~PAID~~ \$ 1557.83

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE:	START LOCK UP:	START LOCK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 12/10/25
 Name Eugene Turner Company Sikes Propane, Inc.
 Address 302 Dixon Rd. S.E. Call Taken By _____
 City Surrency State GA Zip 31563 Telephone (Cell) _____ (Home) _____

Appliance Check

Appliance	water heater	Generator	Gas Logs		
Manufacturer	<u>Rinnai</u>	<u>Generac</u>	<u>Peterson</u>		
Model #	<u>RE180e</u>	<u>G0070432</u>	<u>G10-24/30</u> <u>-15 (M)P</u>		
Serial #	<u>TH. UA-116</u> <u>501</u>	<u>3004656118</u>	<u>1566765</u>		
BTU's	<u>180,000</u>	<u>355,000</u>	<u>37,000</u>		
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>		
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>existing</u>	<u>existing</u>		
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>		
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>		
Age	<u>new</u>	<u>2yrs.</u>	<u>6yrs.</u>		
Taken Out Of Service Or Operation					

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>200</u>	<u>1K05286</u>	<u>American W.</u>	<u>1988</u>	<u>ok</u>	<u>ok</u>	<u>12-87</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>115psi.</u>	<u>115psi.</u>	<u>10min.</u>	<input checked="" type="radio"/> Y <input type="radio"/> N	<input type="radio"/> 0 <input type="radio"/> X

Piping Check

Materials	Size	Cover / Protection
<u>copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<input checked="" type="radio"/> Y <input type="radio"/> N	<input type="radio"/> 0 <input type="radio"/> X

Regulator Check

Type	Manufacturer	Date / Model	Vent Position/ Protection
<u>first</u>	<u>Rego</u>	<u>04-2019 / LV4403TR9</u>	<u>n-c</u>
<u>second</u>	<u>Rego</u>	<u>10-2018 / LV3403B4</u>	<u>down</u>
<u>second</u>	<u>Rego</u>	<u>01-2019 / LV4403B66</u>	<u>down</u>
<u>second</u>	<u>Rego</u>	<u>04C2025 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.