



INVOICE  
No. 11043

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515  
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Bhane Johnston</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>520 Heath St.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley, Ga 31513</u>	DATE PROMISED	
PHONE	<u>912-367-6881</u>	DATE COMPLETED	<u>12-19-25</u>
LOCATION		TERMS	

INSTRUCTIONS install two tankless water heaters, + six gas cooktops, set 250 gallon tank, run gas lines

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
2	Rinnai RE199e tankless water heater w/ isolation valves, serial # RE.4A-070996, SH.4A-117754	1500 00	3000 00
6	30" stainless steel gas cooktop	300 00	1800 00
55'	1/2" Trac Pipe Constar Strike	5 09	279 95
1	1/2" Trac Pipe auto flare tee		57 95
3	1/2" Trac Pipe auto flare male adaptor	25 50	76 50
76'	1/2" coated copper tubing	3 49	265 24
24	1/2" flare nut	1 60	38 40
4	1/2" cut off valve	16 95	67 80
All	other gas fittings, pex fittings, thread sealant, stud guards		88 70

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:  1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>  2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>installed two tankless water heaters, and six gas cooktops, set 250 gallon tank, ran all gas lines, converted cooktops to LP, ran pressure check, lit &amp; checked out appliances</u>	TOTAL MATERIAL <u>5,674 54</u>
	TOTAL TIME _____ HOURS LABOR <u>1200 00</u>	SUBTOTAL <u>6874 54</u>
THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.  X _____ CUSTOMER'S SIGNATURE	SERVICES PERFORMED BY <u>Daniel Sikes</u>	SALES TAX TOTAL DUE <u>6874 54</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1548504</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>0%</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPGA rebate 400.00 AMOUNT  
~~EXPENSE~~ \$ 6474.54  
 RECEIVED BY \_\_\_\_\_  
 DATE \_\_\_\_\_  
 SERVICES RECEIVED BY \_\_\_\_\_

# GASCheck - Gas Appliance System Check

Account Name \_\_\_\_\_ Invoice Number \_\_\_\_\_ Date 12/19/25  
 Name Shane Thornton Company Sikes Propane, Inc.  
 Address \_\_\_\_\_ Call Taken By \_\_\_\_\_  
 City Baxley State GA Zip 31513 Telephone (Cell) \_\_\_\_\_ (Home) \_\_\_\_\_

## Appliance Check

Appliance	water heater	water heater	cooktop			
Manufacturer	<u>Rinnai</u>	<u>Rinnai</u>	<u>Dali-kit</u>			
Model #	<u>RE199e</u>	<u>RE199e</u>	<u>DK257-A10</u>			
Serial #	<u>RE.UA-07 0996</u>	<u>SH.UA-117 754</u>	<u>N/A</u>			
BTU's	<u>199,000</u>	<u>199,000</u>	<u>N/A</u>			
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>	<u>installed</u>			
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Age	<u>new</u>	<u>new</u>	<u>new</u>			
Taken Out Of Service Or Operation			<u>(X6)</u>			

## Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1548504</u>	<u>Quality Steel</u>	<u>2025</u>	<u>ok</u>	<u>new</u>	<u>03623</u>	<u>ok</u>

## Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>95 psi.</u>	<u>95 psi.</u>	<u>10 min.</u>	<input checked="" type="radio"/> N
			Work Order <input checked="" type="radio"/> N

## Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>
<u>Trac Pipe</u>	<u>1/2"</u>	<u>ok</u>

## System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<input checked="" type="radio"/> N
			Work Order <input checked="" type="radio"/> N

## Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rego</u>		
<u>Second</u>	<u>Rego</u>		

## Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.