



INVOICE
No. 11069

HOME OWNED & OPERATED

P.O. BOX 508 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Brad Rantz @ Migrant House</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>215 Harmony Church Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	_____
PHONE	<u>912-278-4870</u>	DATE COMPLETED	<u>1-9-26</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS install two tankless water heaters + six gas cooktops, run all gas lines

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
2	Rinnai RE199e tankless water heater w/isolation valves, ser#TF.UA-087294, ser#TL.UA-166354	1500 00	3000 00
140'	1/2" coated copper tubing	3 49	488 60
4	1/2" cut off valve	16 95	67 80
6	1/2" tee	4 59	27 54
27	1/2" flare nut	1 60	43 20
6	1/2" x 1/2" female adaptor	2 59	15 54
4	1/2" swivel	3 99	15 96
All	other gas fittings, thread sealant		41 80
1	Rego LV4403B66 second stage regulator		69 95

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>installed two tankless water heaters, + six gas cooktops, ran all gas lines, converted cooktops to LP, ran pressure check, lit + checked out appliances</u>	TOTAL MATERIAL	<u>3770 39</u>
	TOTAL TIME HOURS	LABOR	<u>620 00</u>

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME. X _____ CUSTOMER'S SIGNATURE	SERVICES PERFORMED	SUBTOTAL	
	BY <u>Daniel H.</u>	SALES TAX	
		TOTAL DUE	<u>4390 39</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-GPGA rebate: 400.00 AMOUNT RECEIVED \$ <u>3990.39</u>
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		
SIZE:	SIZE	HIGH	LOW	RECEIVED BY _____ DATE _____ SERVICES RECEIVED BY _____
S/N:	S/N:	START LOCK UP:	START LOCK UP:	
GALLONS OR READING:	GALLONS OR READING:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	
		AFTER 10 MINUTES:	AFTER 10 MINUTES:	
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 1/9/26
 Name Brad Rantz @ Migrant House Company Sikes Propane, Inc.
 Address 215 Harmony Church Rd. Call Taken By _____
 City Roxley State GA Zip 31513 Telephone (Cell) 912-278-4870 (Home) _____

Appliance Check

Appliance	water heater	water heater	cooktop	cooktop	water heater	water heater
Manufacturer	Rinnai	Rinnai	Dal: kit	Dal: kit	Rinnai	Rinnai
Model #	RE199e	RE199e	DK257-A10	DK257-A01	RE199e	RE199e
Serial #	TF.4A-087294	TL.4A-166354	N/A	N/A	RC.4A-047786	RC.4A-047781
BTU's	199,000	199,000	N/A	N/A	199,000	199,000
Burner / Cam. Chamber	ok	ok	ok	ok	ok	ok
Man. Shutoff / Sed. Trap	installed	installed	installed	existing	existing	existing
Control / Pilot Safety System	ok	ok	ok	ok	ok	ok
Venting System	ok	ok	ok	ok	ok	ok
Age	new	new	new	2yrs.	2yrs.	2yrs.
Taken Out Of Service Or Operation			(X6)			

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	73188	Jackson Tank	1964	ok	ok	03A23	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
120 psi.	120 psi.	10 min.	0
			Work Order 0

Piping Check

Materials	Size	Cover / Protection
coated copper	1/2"	ok
trac pipe	1/2"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9 in. wc	9 in. wc	10 min.	0
			Work Order 0

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
First	Rago	10D2022 / LV4403TR9	n-c
Second	Rago	08B2024 / LV4403B66	down
Second	Rago	10B2022 / LV4403B66	down

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.