

- SALES
- SERVICE
- INSTALLATION



RH/AJ

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number <b>890504</b>	Date Written <b>12/31/25</b>	Taken By <b>WS</b>	Schedule Date <b>1/5/26</b>	Date Compl <b>1/5/26</b>
Branch - Customer No. <b>1-18938</b>	Home <b>813 390-2902</b>	Work	Time Started <b>10:00</b>	Time Completed <b>2:30</b>

Name: **JAY LANGFORD**  
 Address: **3124 WEST KENSINGTON AVE**  
 City: **TAMPA, FL 33269** State: **FL** Zip: **33621-8922**

Service Address: **1726 Jerusalem Church Rd, Canulla, GA 31730-7157**  
~~3124 WEST KENSINGTON TAMPA, FL 33269~~

\* Did not install controller no wire  
 \* did not connect Rinnai plumber needed

Work to be performed: **APPROX 100'**  
**RUN YARD LINE (DITCH ALREADY DUG) CONNECT TO HOUSE. INSTALL RINNAI & FIRE OFF**

Work completed: **Ran yard line from tank to house installed Rinnai pressure control system**

CALLLED IN BY JAY LANGFORD  
 CONTRACTOR: JIMMY HUMPRIES - 229-225-5677

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	WR-RE199eP Rinnai		1094.00	1	WR-RIKF		98.00
1	WR-MC601W		139.00	1	WR-PCD09-SHS		162.00
(1)	R122H-AAJ		59.71	1	CR LV4403B66RA		86.11
1	NG POB		717.86				

**FISHER** LOC 105  
 TYPE: R122H-AAJ  
 ORIFICE: 0.15"  
 SPG RANGE: 10PSI  
 INTERNAL RELIEF  
 MAX. INLET: 250PSI  
 MFG DATE: 24-Sep-25  
 ID:003898703

Manometer Reading at Start <b>915</b>	Manometer Reading After 10 minutes <b>915</b>	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES	<b>16.50</b>
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	<b>2373.18</b>
Manufacturer <b>Rinnai</b>	Model No. <b>RE199eP</b>	Serial No. <b>TJ.UA139109</b>	Sed. Trap Vent	TRIP CHARGE	
Fuel/BTU 000 <b>199</b> 000	N/A	N/A	000	LABOR	
AGE <b>New</b>				SUB-LABOR	<b>(200.00)</b>
Shut off installed				PERMIT	
				SHIPPING/FREIGHT	
				Thank You	SALES TAX <b>189.86</b>
					TOTAL <b>2363.04</b>

CASH RECEIVED BY \_\_\_\_\_

CHECK

Work Completed by: **Toby H AJC** Date: **1/5/26**

Customer Signature: \_\_\_\_\_ Date: **1/5/26**

ANY UNUSED GAS PIPING OUTLETS INDOORS?  YES  NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?  YES  NO

CUSTOMER AVAILABLE  YES  NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE  YES  NO

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY