



congerlpgas.com

INVOICE / WORK ORDER NO.

111069

Breg

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

NAME Sue Hobby Scoggins RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 2-24435 DATE 1-8-26 INT \_\_\_\_\_

MAILING ADDRESS 305 College St CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS \_\_\_\_\_ APT/LOT NO. \_\_\_\_\_

CITY SUMNER STATE GA ZIP CODE \_\_\_\_\_

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED:  CASH  CHARGE DATE PROMISED \_\_\_\_\_

quote install w/h

email: \_\_\_\_\_  
cell # 296-4379  
**PAY BILL ONLINE @congerlpgas.com**

DIRECTIONS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>Set</u>	<u>120</u>	<u>4700</u>	<u>4</u>	<u>5 Gallons</u>	<u>3.849 @</u>	<u>19.25</u>			

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Rinnai RE150E Water Heater</u>	<u>RE150E</u>	<u>TFUA-084779</u>	<u>(W/H) 1199.95</u>	<u>1199.95</u>
<u>2</u>	<u>3/8 nuts</u>			<u>1.95</u>	<u>3.90</u>
<u>26'</u>	<u>3/8 Copper</u>			<u>3.95</u>	<u>102.70</u>
<u>1</u>	<u>Sedco Trap</u>			<u>49.95</u>	<u>49.95</u>
<u>1</u>	<u>LV4403B46R Reg</u>			<u>79.95</u>	<u>79.95</u>
<u>1</u>	<u>1/2 x 1/2 MIP copper</u>				<u>19.95</u>
<u>1</u>	<u>3/8 x 1/2 MIP</u>				<u>3.95</u>
				<u>(TR)</u>	<u>120.00</u>
				<u>(OT)</u>	<u>19.25</u>

WORK PERFORMED: <u>Set Tank Pans &amp; Line to WH &amp; Installed w/h</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
MAKE: <u>Kevo</u>	MODEL: <u>LV3403TA9</u>	PARTS/MAT. USED	<u>(MP)</u>
DATE CODE: <u>5-25</u>	VENT: <u>Down</u>	TANK RENT	<u>(MS)</u>
			<u>GR</u>
			<u>CF</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE		SALES TAX	
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		%	<u>96.00 20.80</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	LEAK AND PRESSURE TEST		<u>2.21 9.60</u>
	HIGH: 1st Stage	2nd Stage	LOW
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP: <u>9.0</u> PSI	PSI	START LOCK-UP: <u>12.3</u> W.C.
	TANK OFF: PRESSURE <u>6.0</u> PSI	PSI	TANK OFF: PRESSURE <u>9.1</u> W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.			
	AFTER 10 MINUTES: <u>6.0</u> PSI	PSI	AFTER 10 MINUTES: <u>9.1</u> W.C.
	PRESSURE AS LEFT: <u>9.0</u> PSI	PSI	PRESSURE AS LEFT: <u>11.0</u> W.C.
X	PIPING PRESSURE TEST		LABOR
CUSTOMER SIGNATURE	START <u>6.0</u> PSIG	FINISH <u>6.0</u> PSIG	INV. TOTAL
			<u>200.00</u>
			<u>1776.30</u>
			AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature]  
SERVICE REP. SIGNATURE

1-13-26  
DATE

X \_\_\_\_\_  
CUSTOMER SIGNATURE