

SALES
SERVICE
INSTALLATION



RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 892113	Date Written 1/16/26	Taken By: MEH	Schedule Date 1/19/26	Date Completed 1-19-2026
Branch - Customer No. 1-42928	Home 910 297-5891	Work	Time Started 9:00 A.M. P.M.	Time Completed 4:45 A.M. P.M.
Name VINCENT HUTCHERSON	Address 2331 BEATTIE RD ALBANY, GA		Cell Zip 31721-7111	
Service Address 2331 BEATTIE RD ALBANY, GA 31721		GILLIONVILLE RD RT ON BEATTIE. HO ON LFT 14 PEOPLE LIVE HERE!! CELL 910-297-4900 *H/WATER ONLY*		

Work to be performed: DELIVER AND INSTALL RINNAI RX199iN WITH INSTALL KIT, 184162PP CONDENSING ROOF DISCHARGE TERMINAL, 189958 FLASHING, AND MC-601-W CONTROLLER. CALLED IN BY VINCENT. 910-297-5891 CELL: up ✓ GAY

Work completed: Delivered installed and RIKF Vented Rinnai performed plumbing NG. POB \$68.02

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	W-R 11470 CAMCO Drain Pin	39.00		1	W-R RX199iN/P Rinnai Water Heater		1553.00
3	3/4 mip x pex		12.21	1	W-R RIKF Install kit		95.00
2	3/4 pex EL		5.96	1	W-R 184162PP Condensing Roof Discharge		84.00
9	3/4 pex Rings		3.72	1	W-R 189958 Flashing		92.00
1	1/2 Pip x 1/2 pvc 2-1/2 pvc	.89	1.80	1	W-R MC601-W Controller		146.00
2	1/2 pvc 90°		.66	2	1" pvc 90° 1-2" pvc Roof Flash	3.82	7.64
				1	1" pvc coup.		.87
				4	2" pvc 3-2" pvc 90°		34.08

DR. RT.	Rt. Seq.	Rate	Deposit	Manometer Reading at Start 7	Manometer Reading After 10 minutes 7	Manometer Reading Under Load 11.5	Manometer Reading 13	SHOP OR TRUCK SUPPLIES	16.50
Tank Make	Size 330	Serial No. N9398CH	Tank Percent 50%	MATERIAL TOTAL		1773.50		TRIP CHARGE	
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	LABOR		
TWO 1st	04E05	Good	Rego	LV404B4	Her	Dome	SUB-LABOR - Rebate	<200.00>	
STAGE 2nd							PERMIT		
Less Check				Flow Check		Lock-up Check		SHIPPING/FREIGHT	
Central Heating		Water Heater		Range		Clothes Dryer		Thank You	SALES TAX
Manufacturer		Rinnai						TOTAL	141.88
Model No.		RX199i						ANY UNUSED GAS PIPING OUTLETS INDOORS?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Serial No.		TG.BA-17387A						IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Sed. Trap		I I						CUSTOMER AVAILABLE	<input type="checkbox"/> YES <input type="checkbox"/> NO
Vent								CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE	<input type="checkbox"/> YES <input type="checkbox"/> NO
Fuel/BTU		000 199 000		N/A		N/A			
AGE		New							
Shut off Installed									

CASH RECEIVED BY Internal unit

CHECK

Work Completed by Curtis Royce Date 1-19-2026

Customer Signature [Signature] Date 1-19-2026

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY