



congerlpgas.com

INVOICE / WORK ORDER NO.

Ga:

127595

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Lewis Taylor Farms RT# _____ RT. SEQ. _____ ACCT # 1-14145 DATE 6-1-26 INT 5.5

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 1616 W.B. Parks Rd APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31793

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: Harvey

cell # 229-821-0093

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Barracks #3
Hot water heater beeping
Charles @ lewistaylorfarms.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rel802	Rel802	TL-WA-163735		1199.95
	misc supplies				6.00

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
Replaced w/h	MAKE: <u>Regu</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	4199.95
	DATE CODE: <u>04/303</u> VENT: <u>Down</u>	TANK RENT	6.00

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58	☐	HIGH:	1st Stage	2nd Stage	LOW	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54	☐	START LOCK-UP:	9.2 PSI		START LOCK-UP:	12.6 W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF:	6.0 PSI		TANK OFF:	9.0 W.C.
		AFTER 10 MINUTES:	6.0 PSI		AFTER 10 MINUTES:	9.0 W.C.
		PRESSURE AS LEFT:	9.0 PSI		PRESSURE AS LEFT:	11.0 W.C.
X _____ CUSTOMER SIGNATURE		PIPING PRESSURE TEST			INV. TOTAL	1,222.90
		START	6.0 PSIG	FINISH	6.0 PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Justin Stabolt
SERVICE REP. SIGNATURE

June 1st 2026
DATE

CUSTOMER SIGNATURE