



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID HOLSHE
Account # 8085
Invoice # S0014526
Invoice Date 6/16/2026

Sold To

SHELDON HOLLAND
478 BARROW RD
REYNOLDS, GA 31076

Shipped To Location 2

SHELDON HOLLAND
378 BARROW RD
REYNOLDS, GA 31076

Date 6/16/2026
Salesperson 5
PO #

Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
75.00	12R50	1/2" COPPER TUBING	4.0000	\$300.00
		REGULAR SALES TAXABLE		24.00
6.00	40-10	5/8" Flare Nut	3.2500	\$19.50
		REGULAR SALES TAXABLE		1.58
13.00	58R50	5/8" Copper Tubing	5.5000	\$71.50
		REGULAR SALES TAXABLE		5.74
10.00	40-8	1/2" Flare Nut	2.5000	\$25.00
		REGULAR SALES TAXABLE		2.00
2.00	42-8	1/2" Flare Union	3.0000	\$6.00
		REGULAR SALES TAXABLE		0.48
1.00	44-10-10-8	5/8X5/8X1/2 Flare Tee	6.7500	\$6.75
		REGULAR SALES TAXABLE		0.55
3.00	39-8	1/2" SWIVEL NUT	5.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
2.00	55-8	1/2"X1/2" Flare Elbow	3.7500	\$7.50
		REGULAR SALES TAXABLE		0.62
2.00	48-8-8	1/2"X1/2" FI X Male Conn	2.8500	\$5.70
		REGULAR SALES TAXABLE		0.47
2.00	48-10-12	5/8X3/4 FI X Male Conn	4.2500	\$8.50
		REGULAR SALES TAXABLE		0.70
1.00	46-8-8	1/2"X1/2" FI X Fem Conn	1.1000	\$1.10
		REGULAR SALES TAXABLE		0.08
2.00	491002	3/4 Cutoff	15.0000	\$30.00
		REGULAR SALES TAXABLE		2.40
2.00	LV4403B4	2nd Stage Regulator	74.7800	\$149.56
		REGULAR SALES TAXABLE		11.98
1.00	44-8	1/2" Flare Tee	5.0000	\$5.00
		REGULAR SALES TAXABLE		0.40
1.00	45035	1/2" Black 90 St Elbow	3.6000	\$3.60
		REGULAR SALES TAXABLE		0.30
1.00	50-10-8	5/8"X1/2" FI Fem Elbow	3.5000	\$3.50
		REGULAR SALES TAXABLE		0.30
1.00	3552335	MEC Regulator Bracket	5.1200	\$5.12
		REGULAR SALES TAXABLE		0.40
1.00	RE180EP	Rinnai Water Heater	1,385.0000	\$1,385.00
		REGULAR SALES TAXABLE		110.80
1.00	PCD09-SHS	Rinnai Pipe Cover	225.0000	\$225.00
		REGULAR SALES TAXABLE		18.00
1.00	MIVK-T-LW	Plumbing kit for rinnai	150.0000	\$150.00



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID HOLSHE
Account # 8085
Invoice # S0014526
Invoice Date 6/16/2026

Sold To
SHELDON HOLLAND
478 BARROW RD
REYNOLDS, GA 31076

Shipped To Location 2
SHELDON HOLLAND
378 BARROW RD
REYNOLDS, GA 31076

Date 6/16/2026
Salesperson 5
PO #

Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
		REGULAR SALES TAXABLE		12.00
1.00		PERF REBATE	-200.0000	(\$200.00)
1.00		LABOR	250.0000	\$250.00
1.00		Tank Set	0.0000	\$0.00
1.00		TANK LEASE	72.0000	\$72.00
		REGULAR SALES TAXABLE		5.76
100.00		GAS IN TANK	2.5000	\$250.00
		REGULAR SALES TAXABLE		20.00

Subtotal	\$2,795.33
GA TAYLOR CO TAX	\$219.76
HEADER	
Invoice Total	\$3,015.09
Total Due	\$3,015.09



PROPANE SAFETY INSPECTION



Account # 8085 Name SHELDON HOLLAND Address [2] 378 BARROW RD City REYNOLDS

State GA Zip 31076 Phone 9418007070 Date of Inspection 05/26/2026 Branch/Location _____ Work Order # _____

Equipment Type	Water Heater	Water Heater			
Manufacturer	Rinnai	Rinnai			
Year Manufactured					
Model #	Re180e	Re180e			
Serial #	Th.ua-119754	Tb.ua-022621			
Fuel	Propane	Propane			
BTUs (Maximum Input)	180,000	180,000			
Manual Shutoff Valve	OK	OK			
Sediment Trap					
Burner(s) Condition	OK	OK			
Combustion Chamber Condition	OK	OK			
Control/Pilot Safety System	OK Electronic	OK Electronic			
Venting System	N/A or No	N/A or No			
Combustion Air	Service Not Provided	Service Not Provided			
Taken Out of Svc or Operation (Tag #)	No	No			

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/DOT	AG/UG/AGUG					Last Regual Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	2sg065050		ASME	AG	250 wg		American Welding	2003	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING		Material	Size	Protection	REGULATOR(S)		Mfr.	Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	CT (Copper Tubing)	1/2	OK		1st Stg	REGO	Lv404y9	2025	OK	OK	OK
	2nd Stg	CT (Copper Tubing)	5/8	OK		2nd Stg	REGO	Lv4403b4	2025	OK	OK	OK
						2nd Stg	REGO	Lv4403b4	2025	OK	OK	OK

CSST TRACKING	Bonded	☐ Yes ☐ No ☐ Unknown	Jurisdictional Acct.	☐ Y ☒ N ☐ Unknown	Gas Lines Capped	☒ Y ☐ N/A	Heat Pump	☐ Y ☒ N
---------------	--------	---	----------------------	---	------------------	--	-----------	--

System Type	System Leak Check ☒ Entire System				Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time	Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
1st Stage	2 / 2 ☐ WC ☐ PSI	2 ☐ WC ☐ PSI	11:00	11:15	2 PSI	2 PSI	10:50	11:00	2 ☐ WC ☐ PSI	2.5 ☐ WC ☐ PSI		
	☐ WC ☐ PSI	☐ WC ☐ PSI			PSI	PSI			☐ WC ☐ PSI	☐ WC ☐ PSI		
	☐ WC ☐ PSI	☐ WC ☐ PSI			PSI	PSI			☐ WC ☐ PSI	☐ WC ☐ PSI		
	☐ WC ☐ PSI	☐ WC ☐ PSI			PSI	PSI			☐ WC ☐ PSI	☐ WC ☐ PSI		

Performed Sniff Test	☒ Y ☐ N	Comments	Ran lines installed water heaters set tank installed regulators.;
----------------------	--	----------	---

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☒ Property Owner ☐ Tenant ☐ Authorized Representative, **acknowledge** that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. I further acknowledge that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- ☒ Propane Safety Booklet (PRC-005606 or PRC-101063)
- ☒ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
- ☒ Carbon Monoxide Brochure (PRC-000075)

Tyler Robinson
Service Technician Name - Print

Service Technician Signature
05/26/2026
Date

SHELDON HOLLAND
Customer Name - Print
Customer not available to sign
05/26/2026
Date